



UST TESTING/INSPECTION RESULTS SUMMARY

OWNER NAME: Singh Brothers Petroleum Inc
 ADDRESS: 1245 S Main Street
 CITY/STATE/ZIP: Elkhart, IN 46516

TESTING DATE: 10/10/2023

LOCATION NAME: Citgo Elkhart
 LOCATION ADDRESS: 1245 S Main Street
 LOCATION CITY/STATE: Elkhart, IN 46516
 LOCATION FID#: 01633

THREE YEAR TESTS/INSPECTIONS

SPILL BUCKET INTERGRITY TESTING

COMPLETED

TANK NO	PRODUCT	CONSTRUCTION	RESULT
1	RUL	Single-Walled	PASS
2	DSL	Single-Walled	FAIL
3	PUL	Single-Walled	PASS

HYDROSTATIC SUMP TEST

NOT PERFORMED

SUMP ID	MATERIAL	DEPTH	HYDROSTATIC RESULT	VISUAL RESULT

OVERFILL EQUIPMENT INSPECTION

COMPLETED

TANK	PRODUCT	TYPE	BALL FLOAT RESULT	AUTO SHUT OFF RESULT
1	RUL	Automatic Shutoff Valve		PASS
2	DSL	Automatic Shutoff Valve		FAIL
3	PUL	Automatic Shutoff Valve		PASS

OVERFILL ALARM TEST

NOT PERFORMED

TANK	PRODUCT	BRAND/MODEL	RESULT

LEGEND:

RUL	Regular Unleaded
DSL	Diesel
PUL	Premium Unleaded
KER	Kerosene
ODSL	Off Road Diesel
REC	Recreational

RECOMMENDATIONS:

SITE PHOTOS

TEST DATE: 10/10/2023
 LOCATION NAME: Citgo Elkhart
 LOCATION ADDRESS: 1245 S Main Street
 LOCATION CITY/STATE: Elkhart, IN 46516
 LOCATION PHONE: 317-645-0215
 LOCATION CONTACT: Tanks Data / Virendar Kumar

OWNER NAME: Singh Brothers Petroleum Inc
 OWNER ADDRESS: 1245 S Main Street
 OWNER CITY/STATE/ZIP: Elkhart, IN 46516
 LOCATION FID#: 01633
 WORK ORDER NO: NE-0545

SITE VIEW



NO DSL OVERFILL POSSIBLE BALL VALVE BUT NOT ACCESSIBLE TO VERIFY



RUL OVERFILL EQUIP TEST



PUL OVERFILL EQUIP TEST



SITE PHOTOS

TEST DATE: 10/10/2023
LOCATION NAME: Citgo Elkhart
LOCATION ADDRESS: 1245 S Main Street
LOCATION CITY/STATE: Elkhart, IN 46516
LOCATION PHONE: 317-645-0215
LOCATION CONTACT: Tanks Data / Virendar Kumar

OWNER NAME: Singh Brothers Petroleum Inc
OWNER ADDRESS: 1245 S Main Street
OWNER CITY/STATE/ZIP: Elkhart, IN 46516
LOCATION FID#: 01633
WORK ORDER NO: NE-0545

RUL SPILL BUCKET TEST START 11.5"



RUL SPILL BUCKET TEST END 11.5"



PUL SPILL BUCKET TEST START 11"



PUL SPILL BUCKET TEST END 11"



SITE PHOTOS

TEST DATE: 10/10/2023
LOCATION NAME: Citgo Elkhart
LOCATION ADDRESS: 1245 S Main Street
LOCATION CITY/STATE: Elkhart, IN 46516
LOCATION PHONE: 317-645-0215
LOCATION CONTACT: Tanks Data / Virendar Kumar

OWNER NAME: Singh Brothers Petroleum Inc
OWNER ADDRESS: 1245 S Main Street
OWNER CITY/STATE/ZIP: Elkhart, IN 46516
LOCATION FID#: 01633
WORK ORDER NO: NE-0545

DSL SPILL BUCKET TEST START 13"



DSL SPILL BUCKET TEST END 13"





CERTIFICATION VERIFICATION

Singh Brothers Petroleum Inc
1245 S Main Street
Elkhart, IN 46516


Testing Date: 10/10/2023
Citgo Elkhart
Location of Test: 1245 S Main Street
Elkhart, IN 46516
Site FID#: 01633
Service Technician:
Certified Technician: ADAM WILDER

0

Midwest ECS has completed the following tests/inspections at the above noted location:

ATG Functionality	
Leak Detector	
Elec Line Leak Detector	
Product Line Testing	
Liquid Sensor Functionality	
Spill Bucket	X
Containment Hydrostatic Sump	
Overfill Equipment Inspection	X
Overfill Alarm	
Vent Valve	
Interstitial	
Non-Volumetric Tank Tightness	
Shear Valve Inspection	

I, ADAM WILDER, the certified technician, was present throughout the duration of the testing and/or inspection performed by Midwest ECS at the above address on the above date. I affirm that the testing was done in accordance with Rule 229 IAC 9 and 40CFR Part 80, is accurate based upon the results received and that these forms accurately reflect the results of the testing and/or inspection.

Technician Signature: 

Technician Printed Name: ADAM WILDER

Date & Time: 10/10/2023 @ 3:30PM



INDIANA HOMELAND SECURITY

Underground Storage Tank

ADAM P WILDER
500 SIMS STREET
FRANKFORT, INDIANA

STATE/PERMIT # UC112310	ISSUE 01/30/2023	EFFECTIVE 01/30/2023	EXPIRATION 01/23/2025
----------------------------	---------------------	-------------------------	--------------------------

DISCIPLINES

☒ Installation or Retrofitting	☐ Decommissioning Closure
☐ Cathodic Protection	☐ Decommissioning Removal
☐ Testing	

I attest with my signature below, that this technician was present onsite for testing as described above.

Singh