



CATHODIC PROTECTION - IMPRESSED CURRENT
SOIL TO STRUCTURE/POLARIZATION DECAY

TEST DATE: 8/29/2023
LOCATION NAME: Citgo Elkhart
LOCATION ADDRESS: 1245 S Main St
LOCATION CITY/STATE: Elkhart, IN 46516
LOCATION PHONE: 0
LOCATION CONTACT: Virendar Kumar

OWNER NAME: TANKS DATA
OWNER ADDRESS: 1245 S Main St
OWNER CITY/STATE/ZIP: Elkhart, IN 46516
LOCATION FID#: 1633
WORK ORDER NO: NE-0544

RECTIFIER MANUFACTURER: TANKNOLOGY
MODEL: SSP-JB
SERIAL NO: 981500

	VOLTS	AMPS
DC OUTPUT:	-18	-0.25
COURSE:	1	
FINE:	4	

CONTACT POINT	REFERENCE CELL LOCATION	VOLTAGE CURRENT ON	INSTANT OFF VOLTAGE	FINAL VOLTAGE	VOLTAGE DECAY	RESULT
TANK NO:	1	PRODUCT STORED:	RUL	TANK CAPACITY:		
STP	STP	-1163		-982		PASS
STP	TM	-1155		-972		PASS
TM RISER	TM	-1246		-1002		PASS
TANK NO:	2	PRODUCT STORED:	DSL	TANK CAPACITY:		
STP	STP	-1201		-1009		PASS
STP	TM	-1220		-1021		PASS
TM RISER	TM	-1236		-978		PASS
TANK NO:	3	PRODUCT STORED:	PUL	TANK CAPACITY:		
STP	STP	-1240		-950		PASS
STP	TM	-1196		-899		PASS
TM RISER	TM	-1630		-967		PASS
TANK NO:		PRODUCT STORED:		TANK CAPACITY:		
TANK NO:		PRODUCT STORED:		TANK CAPACITY:		
TANK NO:		PRODUCT STORED:		TANK CAPACITY:		
TANK NO:		PRODUCT STORED:		TANK CAPACITY:		
TANK NO:		PRODUCT STORED:		TANK CAPACITY:		
TANK NO:		PRODUCT STORED:		TANK CAPACITY:		

NOTES:

JOHN LANNOM
CERTIFIED TECHNICIAN NAME (printed)


CERTIFIED TECHNICIAN SIGNATURE

CERT NO: UC20129333
EXPIRATION DATE: 8/17/2024