

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN
10/28/2024 5:59 PM

REGULATORY REPORT

HARDWARE STATUS

TS-C1M NOT INSTALLED
TS-H0M NOT INSTALLED
TS-SEM 1 NOT INSTALLED
TS-SEM 2 NOT INSTALLED
TS-CPM NOT INSTALLED
PRINTER OPERATIONAL
FAX/MOD OPERATIONAL

PROBES

PROBE 1 OPERATIONAL
PROBE 2 OPERATIONAL
PROBE 3 OPERATIONAL

SENSORS

SENSOR 1 OPERATIONAL
SENSOR 2 OPERATIONAL
SENSOR 3 OPERATIONAL
SENSOR 4 OPERATIONAL
SENSOR 5 OPERATIONAL
SENSOR 6 OPERATIONAL
SENSOR 7 OPERATIONAL
SENSOR 8 OPERATIONAL
SENSOR 9 OPERATIONAL
SENSOR 10 OPERATIONAL
SENSOR 11 OPERATIONAL
SENSOR 12 OPERATIONAL

AUXILIARY INPUTS

AUX IN 1 OPERATIONAL
AUX IN 2 OPERATIONAL

PASSED LEAK TESTS

TANK 1
07/09/2018 6:24 AM
LEAK TEST 0.20 GPH
SLOPE -0.00 GPH

TANK 2
09/04/2019 5:14 AM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

TANK 3
09/04/2019 5:44 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH

PASSED SCALD TESTS

TANK 1
10/27/2024 11:00 PM
LEAK TEST 0.20 GPH
SLOPE -0.03 GPH

10/16/2024 3:05 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

09/17/2024 6:02 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

09/18/2024 1:17 AM
LEAK TEST 0.20 GPH
SLOPE 0.04 GPH

07/22/2024 3:16 AM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

06/26/2024 1:47 AM
LEAK TEST 0.20 GPH
SLOPE 0.06 GPH

05/31/2024 5:46 AM
LEAK TEST 0.20 GPH
SLOPE -0.10 GPH

05/03/2024 6:56 AM
LEAK TEST 0.20 GPH
SLOPE -0.07 GPH

04/03/2024 3:12 AM
LEAK TEST 0.20 GPH
SLOPE -0.07 GPH

03/07/2024 3:09 AM
LEAK TEST 0.20 GPH
SLOPE -0.09 GPH

02/07/2024 8:06 AM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH

01/06/2024 12:46 AM
LEAK TEST 0.20 GPH
SLOPE -0.07 GPH

12/09/2023 3:04 AM
LEAK TEST 0.20 GPH
SLOPE -0.06 GPH

11/09/2023 1:04 AM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH

10/11/2023 11:49 PM
LEAK TEST 0.20 GPH
SLOPE -0.07 GPH

TANK 2
10/28/2024 3:59 PM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

10/07/2024 10:23 PM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

09/07/2024 10:33 PM
LEAK TEST 0.20 GPH
SLOPE 0.03 GPH

08/08/2024 11:43 PM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

07/05/2024 10:52 PM
LEAK TEST 0.20 GPH
SLOPE -0.00 GPH

06/09/2024 11:03 PM
LEAK TEST 0.20 GPH
SLOPE 0.03 GPH

05/10/2024	10:37 PM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH
04/10/2024	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
03/11/2024	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
02/10/2024	9:34 PM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH
01/11/2024	10:50 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
12/12/2023	9:55 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
11/12/2023	11:49 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
10/13/2023	11:23 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
TANK 3	
10/28/2024	3:33 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH
10/06/2024	11:29 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
09/06/2024	10:57 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
08/07/2024	10:26 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
07/08/2024	9:18 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
06/08/2024	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
05/09/2024	10:24 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
04/09/2024	11:35 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH
03/10/2024	10:32 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
02/09/2024	8:15 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
01/10/2024	12:48 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
12/12/2023	11:26 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
11/12/2023	10:17 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
10/13/2023	8:14 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
BROTHERS EXPRESS	
1245 S MAIN	
ELKHART IN	
10/28/2024	6:00 PM
SENSOR STATUS REPORT	
SENSOR NO. 1	
SENSOR 1	
OK	
SENSOR NO. 2	
SENSOR 2	
OK	
SENSOR NO. 3	
SENSOR 3	
OK	
SENSOR NO. 4	
SENSOR 4	
OK	
SENSOR NO. 5	
SENSOR 5	
OK	
SENSOR NO. 6	
SENSOR 6	
OK	
SENSOR NO. 7	
SENSOR 7	
OK	
SENSOR NO. 8	
SENSOR 8	
OK	
SENSOR NO. 9	
SENSOR 9	