

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

07/14/2024 5:51 PM

LEAK TEST REPORT

UNLEAD 12033.0 GAL

UNLEADED

END TIME 12:32 AM
END DATE 09/04/2019
TEST RESULT ABORTED
REASON DISPENSE

DIESEL 10153.0 GAL

DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 95.0%
TEST STARTED 12:30 AM
TEST STARTED 09/04/2019
END TIME 5:14 AM
END DATE 09/04/2019
LEVEL 30.6 IN
GROSS 2789.3 GAL
TEMP 73.2 F
TEST RESULT PASSED

PREMIUM 12033.0 GAL

PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 95.0%
TEST STARTED 12:30 AM
TEST STARTED 09/04/2019
END TIME 5:44 AM
END DATE 09/04/2019
LEVEL 24.9 IN
GROSS 2516.0 GAL
TEMP 73.9 F
TEST RESULT PASSED

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

07/14/2024 5:51 PM

SCALD TEST REPORT

UNLEAD 12033.0 GAL
UNLEADED

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 2:30 AM
TEST STARTED 07/09/2024
STATUS 1000.02
TEST ENDED 2:41 AM
TEST ENDED 07/13/2024

SLOPE 0.034 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DIESEL 10153.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 3:27 PM
TEST STARTED 07/14/2024
STATUS 0.02
TEST ENDED 5:32 PM
TEST ENDED 07/14/2024

SLOPE 0.030 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREMIUM 12033.0 GAL
PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 5:08 AM
TEST STARTED 07/14/2024
STATUS 0.02
TEST ENDED 7:17 AM
TEST ENDED 07/14/2024

SLOPE 0.001 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE