

oil
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #

1633

Contact Number

Facility Name

Conoco

Contact email

Address

12455 Main St, Skharr

Date of Inspection

10/28/24

Operator on Duty Name

1246514

Name of the Person
Conducting Inspection

AKSHIT

Operator Training current

Operator Training
☐ Yes ☐ No

Operator Notified

☐ Yes

☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No

Operator Notified

☐ Yes

☐ No

Release Detection Method

Release Detection
☒ ATG ☐ SIM

☐ SIR

☐ OC

☐ Other

Make and Model

FES TS1001

Does it have paper?

☒ Yes

Operator Notified

☒ Yes

☐ No

Is it in Alarm mode?

☒ Yes

Operator Notified

☒ Yes

☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes

Operator Notified

☒ Yes

☐ No

Necessary Monthly Printout Taken

☒ Yes

Operator Notified

☒ Yes

☐ No

Spill Buckets

☐ Yes

Operator Notified

☒ Yes

☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes

Operator Notified

☒ Yes

☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes

Operator Notified

☒ Yes

☐ No

Fill Ports

☒ Yes

Operator Notified

☒ Yes

☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes

Operator Notified

☒ Yes

☐ No

Pipeline/STP Sumps

☐ Yes

Operator Notified

☒ Yes

☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes

Operator Notified

☒ Yes

☐ No

Under Dispenser Containments (UDC)

☒ Yes

Operator Notified

☒ Yes

☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes

Operator Notified

☒ Yes

☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS
FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com

20220516