

CERT NO: UC111246
EXPIRATION DATE: 09/15/2024



ESTABROOK EZY CHECK SYSTEMS PRODUCT LINE TESTER DATA SHEET

TEST DATE: 10/10/2023
LOCATION NAME: Conoco Elkhart
LOCATION ADDRESS: 1245 S Main Street
LOCATION CITY/STATE: Elkhart, IN 46516
LOCATION PHONE: 317-645-0215
LOCATION CONTACT: Tanks Data/Virendar Kumar

OWNER NAME: Singh Brothers Petroleum
OWNER ADDRESS: 1245 S Main Street
OWNER CITY/STATE/ZIP: Elkhart, IN 46516
LOCATION FID#: 01633
WORK ORDER NO: NE-0755

TANK #						
1	PRODUCT TYPE:	RUL				
	OPERATING SYSTEM:	PRESSURE				
	STP MODEL:	R/J				
	OPERATING PRESSURE:	22				
	TEST PRESSURE:	50				
	ISOLATION:	CHK/VALVE				
	LINE MATERIAL:	STEEL				
TIME	DATA	-/+	GPL	RES	GPH	
12:17	61	0	0.0037	0.0000	0.0000	
12:32	61	0	0.0037	0	0	
12:47	61	0	0.0037	0	0	
			0.0037			
FINAL RESULT PASS AMT OF CHG 0.00						

TANK #						
3	PRODUCT TYPE:	PUL				
	OPERATING SYSTEM:	PRESSURE				
	STP MODEL:	R/J				
	OPERATING PRESSURE:	20				
	TEST PRESSURE:	50				
	ISOLATION:	SILVER BULLET				
	LINE MATERIAL:	STEEL				
TIME	DATA	-/+	GPL	RES	GPH	
12:30	40	0	0.0037	0.0000	0.0000	
12:45	35	-5	0.0037	0.0185	-0.074	
1:00	24	-6	0.0037	0.0222	-0.0888	
			0.0037			
FINAL RESULT FAIL AMT OF CHG -0.0888						

TANK #						
2	PRODUCT TYPE:	DSL				
	OPERATING SYSTEM:	PRESSURE				
	STP MODEL:	R/J				
	OPERATING PRESSURE:	24				
	TEST PRESSURE:	50				
	ISOLATION:	BALL VALVE				
	LINE MATERIAL:	STEEL				
TIME	DATA	-/+	GPL	RES	GPH	
12:58	71.0000	0	0.0037	0.0000	0.0000	
1:13	71.0000	0	0.0037	0	0	
1:28	71	0	0.0037	0	0	
			0.0037			
FINAL RESULT PASS AMT OF CHG 0.00						

TANK #						
	PRODUCT TYPE:					
	OPERATING SYSTEM:					
	STP MODEL:					
	OPERATING PRESSURE:					
	TEST PRESSURE:					
	ISOLATION:					
	LINE MATERIAL:					
TIME	DATA	-/+	GPL	RES	GPH	
BEG LVL		0	0.0037	0.0000	0.0000	
			0.0037			
			0.0037			
			0.0037			
FINAL RESULT - AMT OF CHG						

TANK #						
	PRODUCT TYPE:					
	OPERATING SYSTEM:					
	STP MODEL:					
	OPERATING PRESSURE:					
	TEST PRESSURE:					
	ISOLATION:					
	LINE MATERIAL:					
TIME	DATA	-/+	GPL	RES	GPH	
BEG LVL		0	0.0037	0.0000	0.0000	
			0.0037			
			0.0037			
			0.0037			
FINAL RESULT - AMT OF CHG						

TANK #						
	PRODUCT TYPE:					
	OPERATING SYSTEM:					
	STP MODEL:					
	OPERATING PRESSURE:					
	TEST PRESSURE:					
	ISOLATION:					
	LINE MATERIAL:					
TIME	DATA	-/+	GPL	RES	GPH	
BEG LVL		0	0.0037	0.0000	0.0000	
			0.0037			
			0.0037			
			0.0037			
FINAL RESULT - AMT OF CHG						

0

SERVICE TECHNICIAN NAME (printed)

PATRICK FOLEY
CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE

CERTIFIED TECHNICIAN SIGNATURE

CERT NO: UC111246
EXPIRATION DATE: 09/15/2024