

BROTHERS EXPRESS

1245 S MAIN

ELKHART IN

11/28/2024

5:42 PM

SENSOR STATUS REPORT

SENSOR NO. 1

SENSOR 1

OK

SENSOR NO. 2

SENSOR 2

OK

SENSOR NO. 3

SENSOR 3

OK

SENSOR NO. 4

SENSOR 4

OK

SENSOR NO. 5

SENSOR 5

OK

SENSOR NO. 6

SENSOR 6

OK

SENSOR NO. 7

SENSOR 7

OK

SENSOR NO. 8

SENSOR 8

OK

SENSOR NO. 9

SENSOR 9

OK

SENSOR NO. 10

SENSOR 10

OK

SENSOR NO. 11

SENSOR 11

OK

SENSOR NO. 12

SENSOR 12

OK

BROTHERS EXPRESS

1245 S MAIN

ELKHART IN

11/28/2024

5:42 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL

SENSORS

SENSOR 1	OPERATIONAL
SENSOR 2	OPERATIONAL
SENSOR 3	OPERATIONAL
SENSOR 4	OPERATIONAL
SENSOR 5	OPERATIONAL
SENSOR 6	OPERATIONAL
SENSOR 7	OPERATIONAL
SENSOR 8	OPERATIONAL
SENSOR 9	OPERATIONAL
SENSOR 10	OPERATIONAL
SENSOR 11	OPERATIONAL
SENSOR 12	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

07/09/2018	6:24 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

TANK 2

09/04/2019	5:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

TANK 3

09/04/2019	5:44 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

PASSED SCALD TESTS

TANK 1

11/28/2024	6:22 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

11/15/2024	3:03 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

10/16/2024	3:05 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

09/17/2024	6:02 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

08/18/2024	1:17 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

07/22/2024	3:16 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

06/26/2024	1:47 AM
LEAK TEST	0.20 GPH
SLOPE	0.06 GPH

05/31/2024	5:46 AM
LEAK TEST	0.20 GPH
SLOPE	-0.10 GPH

05/03/2024	6:56 AM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH

04/03/2024	3:12 AM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH

03/07/2024	3:09 AM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH

02/07/2024	8:06 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

01/08/2024	12:46 AM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH

12/09/2023	3:04 AM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH

11/09/2023	1:04 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

TANK 2

11/28/2024	5:33 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

11/06/2024	10:14 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

10/07/2024	10:23 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

09/07/2024	10:33 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

08/08/2024	11:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

07/09/2024	10:52 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

06/09/2024	11:03 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

05/10/2024	10:37 PM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH

04/10/2024	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

03/11/2024	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

02/10/2024	9:34 PM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH

01/11/2024	10:50 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH

12/12/2023	9:55 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

11/12/2023	11:49 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

TANK 3

11/28/2024	5:15 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

11/05/2024	11:02 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

10/06/2024	11:29 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

09/06/2024	10:57 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

08/07/2024	10:26 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

07/08/2024	9:18 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

06/08/2024	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

05/09/2024	10:24 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

04/09/2024	11:35 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH

03/10/2024	10:32 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

02/09/2024	8:15 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

01/10/2024	12:48 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

12/12/2023	11:26 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

11/12/2023	10:17 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH