

BROTHERS EXPRESS  
1245 S MAIN  
ELKHART IN

04/26/2024 1:13 PM

SCALD TEST REPORT

UNLEAD 12033.0 GAL  
UNLEADED

LEAK TEST 0.200 GPH  
LEAK THRESHOLD 0.100 GPH  
INTERVAL 18.0  
VOL QUALIFY 0.0%  
TEST STARTED 12:14 AM  
TEST STARTED 04/26/2024  
STATUS 1000.02  
TEST ENDED 3:35 AM  
TEST ENDED 04/26/2024

SLOPE 0.009 GAL/HR  
TEST RESULT PASSED  
SLOPE EQUALS CALCULATED  
LEAK RATE

DIESEL 10153.0 GAL  
DIESEL

LEAK TEST 0.200 GPH  
LEAK THRESHOLD 0.100 GPH  
INTERVAL 18.0  
VOL QUALIFY 0.0%  
TEST STARTED 10:17 AM  
TEST STARTED 04/26/2024  
STATUS 0.02  
TEST ENDED 12:27 PM  
TEST ENDED 04/26/2024

SLOPE -0.050 GAL/HR  
TEST RESULT PASSED  
SLOPE EQUALS CALCULATED  
LEAK RATE

PREMIUM 12033.0 GAL  
PREMIUM

LEAK TEST 0.200 GPH  
LEAK THRESHOLD 0.100 GPH  
INTERVAL 18.0  
VOL QUALIFY 0.0%  
TEST STARTED 12:45 AM  
TEST STARTED 04/26/2024  
STATUS 9001.02  
TEST ENDED 3:12 AM  
TEST ENDED 04/26/2024

SLOPE -0.082 GAL/HR  
TEST RESULT PASSED  
SLOPE EQUALS CALCULATED  
LEAK RATE