

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

06/26/2025

8:04 PM

SENSOR STATUS REPORT

SENSOR NO. 1
SENSOR 1

OK

SENSOR NO. 2
SENSOR 2

OK

SENSOR NO. 3
SENSOR 3

OK

SENSOR NO. 4
SENSOR 4

OK

SENSOR NO. 5
SENSOR 5

OK

SENSOR NO. 6
SENSOR 6

OK

SENSOR NO. 7
SENSOR 7

OK

SENSOR NO. 8
SENSOR 8

OK

SENSOR NO. 9
SENSOR 9

OK

SENSOR NO. 10
SENSOR 10

OK

SENSOR NO. 11
SENSOR 11

OK

SENSOR NO. 12
SENSOR 12

OK

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

06/26/2025

8:05 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL

SENSORS

SENSOR 1	OPERATIONAL
SENSOR 2	OPERATIONAL
SENSOR 3	OPERATIONAL
SENSOR 4	OPERATIONAL
SENSOR 5	OPERATIONAL
SENSOR 6	OPERATIONAL
SENSOR 7	OPERATIONAL
SENSOR 8	OPERATIONAL
SENSOR 9	OPERATIONAL
SENSOR 10	OPERATIONAL
SENSOR 11	OPERATIONAL
SENSOR 12	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

07/09/2018	6:24 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

TANK 2

09/04/2019	5:14 AM
LEAK TEST	0.20 GPH

09/16/2024 LEAK TEST SLOPE	3:03 AM 0.20 GPH -0.03 GPH
09/17/2024 LEAK TEST SLOPE	3:05 AM 0.20 GPH 0.00 GPH
08/18/2024 LEAK TEST SLOPE	6:02 AM 0.20 GPH 0.00 GPH
07/22/2024 LEAK TEST SLOPE	1:17 AM 0.20 GPH 0.04 GPH
06/26/2024 LEAK TEST SLOPE	3:16 AM 0.20 GPH 0.02 GPH
05/31/2024 LEAK TEST SLOPE	1:47 AM 0.20 GPH 0.06 GPH
06/26/2025 LEAK TEST SLOPE	5:46 AM 0.20 GPH -0.10 GPH
06/04/2025 LEAK TEST SLOPE	TANK 2 6:01 PM 0.20 GPH 0.05 GPH
05/05/2025 LEAK TEST SLOPE	11:28 PM 0.20 GPH 0.02 GPH
04/05/2025 LEAK TEST SLOPE	10:23 PM 0.20 GPH -0.04 GPH
03/06/2025 LEAK TEST SLOPE	10:31 PM 0.20 GPH -0.03 GPH
02/04/2025 LEAK TEST SLOPE	11:29 PM 0.20 GPH -0.00 GPH
01/05/2025 LEAK TEST SLOPE	11:44 PM 0.20 GPH -0.02 GPH
12/06/2024 LEAK TEST SLOPE	11:42 PM 0.20 GPH 0.02 GPH
11/06/2024 LEAK TEST SLOPE	7:35 PM 0.20 GPH 0.00 GPH
10/07/2024 LEAK TEST SLOPE	10:14 PM 0.20 GPH -0.04 GPH
09/07/2024 LEAK TEST SLOPE	10:23 PM 0.20 GPH 0.00 GPH
08/08/2024 LEAK TEST SLOPE	10:33 PM 0.20 GPH 0.03 GPH
07/09/2024 LEAK TEST SLOPE	11:43 PM 0.20 GPH 0.02 GPH
06/09/2024 LEAK TEST SLOPE	10:52 PM 0.20 GPH -0.00 GPH
06/09/2024 LEAK TEST SLOPE	11:03 PM 0.20 GPH 0.03 GPH
06/26/2025 LEAK TEST SLOPE	TANK 3 9:49 AM 0.20 GPH -0.01 GPH
06/03/2025 LEAK TEST SLOPE	2:56 PM 0.20 GPH -0.07 GPH
05/04/2025 LEAK TEST SLOPE	6:49 AM 0.20 GPH -0.03 GPH
04/04/2025 LEAK TEST SLOPE	8:26 AM 0.20 GPH -0.02 GPH
03/05/2025 LEAK TEST SLOPE	10:10 PM 0.20 GPH -0.03 GPH
02/03/2025 LEAK TEST SLOPE	8:16 AM 0.20 GPH 0.07 GPH
01/04/2025 LEAK TEST SLOPE	11:00 PM 0.20 GPH -0.04 GPH
12/05/2024 LEAK TEST SLOPE	9:31 PM 0.20 GPH 0.02 GPH
11/05/2024 LEAK TEST SLOPE	11:02 PM 0.20 GPH 0.01 GPH
10/06/2024 LEAK TEST SLOPE	11:29 PM 0.20 GPH -0.03 GPH
09/06/2024 LEAK TEST SLOPE	10:57 PM 0.20 GPH 0.02 GPH
08/07/2024 LEAK TEST SLOPE	10:26 PM 0.20 GPH 0.00 GPH
07/08/2024 LEAK TEST SLOPE	9:18 PM 0.20 GPH -0.04 GPH
07/08/2024 LEAK TEST SLOPE	11:28 PM 0.20 GPH