

BROTHERS EXPRESS

1245 S MAIN

ELKHART IN

02/27/2025

6:59 PM

SENSOR STATUS REPORT

SENSOR NO. 1

SENSOR 1

OK

SENSOR NO. 2

SENSOR 2

OK

SENSOR NO. 3

SENSOR 3

OK

SENSOR NO. 4

SENSOR 4

OK

SENSOR NO. 5

SENSOR 5

OK

SENSOR NO. 6

SENSOR 6

OK

SENSOR NO. 7

SENSOR 7

OK

SENSOR NO. 8

SENSOR 8

OK

SENSOR NO. 9

SENSOR 9

OK

SENSOR NO. 10

SENSOR 10

OK

SENSOR NO. 11

SENSOR 11

OK

SENSOR NO. 12

SENSOR 12

OK

BROTHERS EXPRESS

1245 S MAIN

ELKHART IN

02/27/2025

6:59 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM NOT INSTALLED

TS-ROM NOT INSTALLED

TS-SEM 1 NOT INSTALLED

TS-SEM 2 NOT INSTALLED

TS-CPM NOT INSTALLED

PRINTER OPERATIONAL

FAX/MOD OPERATIONAL

PROBES

PROBE 1 OPERATIONAL

PROBE 2 OPERATIONAL

PROBE 3 OPERATIONAL

SENSORS

SENSOR 1 OPERATIONAL

SENSOR 2 OPERATIONAL

SENSOR 3 OPERATIONAL

SENSOR 4 OPERATIONAL

SENSOR 5 OPERATIONAL

SENSOR 6 OPERATIONAL

SENSOR 7 OPERATIONAL

SENSOR 8 OPERATIONAL

SENSOR 9 OPERATIONAL

SENSOR 10 OPERATIONAL

SENSOR 11 OPERATIONAL

SENSOR 12 OPERATIONAL

AUXILIARY INPUTS

AUX IN 1 OPERATIONAL

AUX IN 2 OPERATIONAL

PASSED LEAK TESTS

TANK 1

07/09/2018 5:24 AM

LEAK TEST 0.20 GPH

SLOPE -0.00 GPH

TANK 2

09/04/2019 5:14 AM

LEAK TEST 0.20 GPH

SLOPE 0.02 GPH

TANK 3

09/04/2019 5:44 AM

LEAK TEST 0.20 GPH

SLOPE 0.01 GPH

PASSED SCALD TESTS

TANK 1

02/27/2025 5:51 AM

LEAK TEST 0.20 GPH

SLOPE -0.06 GPH

02/09/2025 12:44 AM

LEAK TEST 0.20 GPH

SLOPE -0.10 GPH

01/12/2025 7:47 AM

LEAK TEST 0.20 GPH

SLOPE -0.10 GPH

12/15/2024 1:47 AM

LEAK TEST 0.20 GPH

SLOPE -0.10 GPH

11/15/2024 3:03 AM

LEAK TEST 0.20 GPH

SLOPE -0.03 GPH

10/16/2024 3:05 AM

LEAK TEST 0.20 GPH

SLOPE 0.00 GPH

LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
08/18/2024	1:17 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
07/22/2024	3:16 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
06/26/2024	1:47 AM
LEAK TEST	0.20 GPH
SLOPE	0.06 GPH
05/31/2024	5:46 AM
LEAK TEST	0.20 GPH
SLOPE	-0.10 GPH
05/03/2024	6:56 AM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH
04/03/2024	3:12 AM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH
03/07/2024	3:09 AM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH
02/07/2024	8:06 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

TANK 2

02/27/2025	4:58 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
02/04/2025	11:44 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
01/05/2025	11:42 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
12/06/2024	7:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
11/06/2024	10:14 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
10/07/2024	10:23 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
09/07/2024	10:33 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
08/08/2024	11:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
07/09/2024	10:52 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
06/09/2024	11:03 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
05/10/2024	10:37 PM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH
04/10/2024	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
03/11/2024	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
02/10/2024	9:34 PM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH

TANK 3

02/27/2025	9:04 AM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH
02/03/2025	8:16 AM
LEAK TEST	0.20 GPH
SLOPE	0.07 GPH
01/04/2025	11:00 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
12/05/2024	9:31 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
11/05/2024	11:02 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
10/06/2024	11:29 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
09/06/2024	10:57 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
08/07/2024	10:26 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
07/08/2024	9:18 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
06/08/2024	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
05/09/2024	10:24 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
04/09/2024	11:35 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH
03/10/2024	10:32 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
02/09/2024	8:15 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH