



# 30 DAYS WALK THROUGH INSPECTION

|                           |                     |                                          |            |
|---------------------------|---------------------|------------------------------------------|------------|
| UST Facility I.D.( FID) # | 1633                | Contact Number                           |            |
| Facility Name             | CONOC               | Contact email                            |            |
| Address                   | 12455 Main St 48514 | Date of Inspection                       | 06-26-2025 |
| Operator on Duty Name     |                     | Name of the Person Conducting Inspection | Guypro     |

|                                                                   |                                                               |                                                                                |                                                               |  |
|-------------------------------------------------------------------|---------------------------------------------------------------|--------------------------------------------------------------------------------|---------------------------------------------------------------|--|
| Operator Training                                                 |                                                               |                                                                                |                                                               |  |
| Operator Training current                                         | <input type="radio"/> Yes <input type="radio"/> No            | Operator Notified                                                              | <input type="radio"/> Yes <input type="radio"/> No            |  |
| Registration/Notification Form                                    |                                                               |                                                                                |                                                               |  |
| Is Registration current with correct owner, operator etc.         | <input type="radio"/> Yes <input type="radio"/> No            | Operator Notified                                                              | <input type="radio"/> Yes <input type="radio"/> No            |  |
| Release Detection                                                 |                                                               |                                                                                |                                                               |  |
| Release Detection Method                                          | <input type="radio"/> ATG <input type="radio"/> CIM           | <input type="radio"/> SIR <input type="radio"/> IC <input type="radio"/> Other |                                                               |  |
| Make and Model                                                    | TS-1001 Tank Sentinel                                         |                                                                                |                                                               |  |
| Does it have paper?                                               | <input checked="" type="radio"/> Yes <input type="radio"/> No | Operator Notified                                                              | <input type="radio"/> Yes <input type="radio"/> No            |  |
| Is it in Alarm mode?                                              | <input checked="" type="radio"/> Yes <input type="radio"/> No | Operator Notified                                                              | <input type="radio"/> Yes <input type="radio"/> No            |  |
| Interstitial Monitoring Sensor Status Normal                      | <input checked="" type="radio"/> Yes <input type="radio"/> No | Operator Notified                                                              | <input type="radio"/> Yes <input type="radio"/> No            |  |
| Necessary Monthly Printout Taken                                  | <input checked="" type="radio"/> Yes <input type="radio"/> No | Operator Notified                                                              | <input type="radio"/> Yes <input type="radio"/> No            |  |
| Spill Buckets                                                     |                                                               |                                                                                |                                                               |  |
| Are Spill Buckets Clean and free from water, debris, product etc? | <input type="radio"/> Yes <input checked="" type="radio"/> No | Operator Notified                                                              | <input checked="" type="radio"/> Yes <input type="radio"/> No |  |
| Are the Spill Bucket in good condition and free of damage/cracks  | <input checked="" type="radio"/> Yes <input type="radio"/> No | Operator Notified                                                              | <input type="radio"/> Yes <input type="radio"/> No            |  |
| Fill Ports                                                        |                                                               |                                                                                |                                                               |  |
| Is Fill pipe cap tight and fill pipe free from any obstruction?   | <input type="radio"/> Yes <input type="radio"/> No            | Operator Notified                                                              | <input type="radio"/> Yes <input type="radio"/> No            |  |
| Piping/STP Sumps                                                  |                                                               |                                                                                |                                                               |  |
| Are Sumps Clean and free from water, debris, product etc?         | <input type="radio"/> Yes <input checked="" type="radio"/> No | Operator Notified                                                              | <input checked="" type="radio"/> Yes <input type="radio"/> No |  |
| Under Dispenser Containments (UDC)                                |                                                               |                                                                                |                                                               |  |
| Are UDCs clean and free from water, debris, product etc?          | <input type="radio"/> Yes <input checked="" type="radio"/> No | Operator Notified                                                              | <input checked="" type="radio"/> Yes <input type="radio"/> No |  |

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

tanksdata@gmail.com

Date 06-26-2025

www.tanksdata.com