

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

07/23/2025 5:05 PM

REGULATORY REPORT

HARDWARE STATUS

S-CIM	NOT INSTALLED
S-ROM	NOT INSTALLED
S-SEM 1	NOT INSTALLED
S-SEM 2	NOT INSTALLED
S-CPH	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL

SENSORS

SENSOR 1	OPERATIONAL
SENSOR 2	OPERATIONAL
SENSOR 3	OPERATIONAL
SENSOR 4	OPERATIONAL
SENSOR 5	OPERATIONAL
SENSOR 6	OPERATIONAL
SENSOR 7	OPERATIONAL
SENSOR 8	OPERATIONAL
SENSOR 9	OPERATIONAL
SENSOR 10	OPERATIONAL
SENSOR 11	OPERATIONAL
SENSOR 12	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

07/09/2018	6:24 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

TANK 2

09/04/2019	5:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

TANK 3

09/04/2019	5:44 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

PASSED SCALD TESTS

TANK 1

07/23/2025	3:03 AM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH

07/08/2025	9:58 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

06/08/2025	7:19 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

05/09/2025	5:02 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

04/10/2025	12:47 AM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH

03/11/2025	11:59 AM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH

02/09/2025	12:44 AM
LEAK TEST	0.20 GPH
SLOPE	-0.10 GPH

01/12/2025	7:47 AM
LEAK TEST	0.20 GPH
SLOPE	-0.10 GPH

12/15/2024	1:47 AM
LEAK TEST	0.20 GPH
SLOPE	-0.10 GPH

11/15/2024	3:03 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

10/16/2024	3:05 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

09/17/2024	6:02 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

08/18/2024	1:17 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

07/22/2024	3:16 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

TANK 2

07/23/2025	3:30 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

07/04/2025	11:39 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH

06/04/2025	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

05/05/2025	10:23 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

04/05/2025	10:31 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

07/17/2024	6:02 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
08/18/2024	1:17 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
07/22/2024	3:16 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
TANK 2	
07/23/2025	3:30 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
07/04/2025	11:39 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH
06/04/2025	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
05/05/2025	10:23 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
04/05/2025	10:31 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
03/06/2025	11:29 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
02/04/2025	11:44 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
01/05/2025	11:42 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
12/06/2024	7:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
11/06/2024	10:14 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
10/07/2024	10:23 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
09/07/2024	10:33 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
08/08/2024	11:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
07/09/2024	10:52 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
TANK 3	
07/23/2025	3:15 AM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH
07/03/2025	11:23 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
06/03/2025	2:56 PM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH
05/04/2025	6:49 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
04/04/2025	8:26 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
03/05/2025	10:10 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
02/03/2025	8:16 AM
LEAK TEST	0.20 GPH
SLOPE	0.07 GPH
01/04/2025	11:00 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
12/05/2024	9:31 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
11/05/2024	11:02 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
10/06/2024	11:29 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
09/06/2024	10:57 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
08/07/2024	10:26 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
07/08/2024	9:18 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

BROTHERS EXPRESS
1245 S MAIN
ELKHART IN

07/23/2025 5:06 PM

SENSOR STATUS REPORT

SENSOR NO. 1

SENSOR 1

OK

SENSOR NO. 2

SENSOR 2

OK

SENSOR NO. 3

SENSOR 3

OK

SENSOR NO. 4

SENSOR 4

OK

SENSOR NO. 5

SENSOR 5

OK

SENSOR NO. 6

SENSOR 6

OK

SENSOR NO. 7

SENSOR 7

OK

SENSOR NO. 8

SENSOR 8

OK

SENSOR NO. 9

SENSOR 9

OK

SENSOR NO. 10

SENSOR 10

OK

SENSOR NO. 11

SENSOR 11

OK

SENSOR NO. 12

SENSOR 12

OK