

BROTHERS EXPRESS
 1245 S MAIN
 ELKHART IN
 09/29/2025 5:25 PM
 STATUS REPORT

SENSOR NO. 1
 OK
 SENSOR NO. 2
 OK
 SENSOR NO. 3
 OK
 SENSOR NO. 4
 OK
 SENSOR NO. 5
 OK
 SENSOR NO. 6
 OK
 SENSOR NO. 7
 OK
 SENSOR NO. 8
 OK
 SENSOR NO. 9
 OK
 SENSOR NO. 10
 OK
 SENSOR NO. 11
 OK
 SENSOR NO. 12
 OK

BROTHERS EXPRESS
 1245 S MAIN
 ELKHART IN
 09/29/2025 5:25 PM

REGULATORY REPORT
 HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL

SENSORS

SENSOR 1	OPERATIONAL
SENSOR 2	OPERATIONAL
SENSOR 3	OPERATIONAL
SENSOR 4	OPERATIONAL
SENSOR 5	OPERATIONAL
SENSOR 6	OPERATIONAL
SENSOR 7	OPERATIONAL
SENSOR 8	OPERATIONAL
SENSOR 9	OPERATIONAL
SENSOR 10	OPERATIONAL
SENSOR 11	OPERATIONAL
SENSOR 12	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

07/09/2018	6:24 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

TANK 2

09/04/2019	5:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

TANK 3

09/04/2019	5:44 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

PASSED SCALD TESTS

TANK 1

09/29/2025	3:19 AM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH

SLOPE
TANK 3
09/04/2019 5:44 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH
PASSED SCALD TESTS

TANK 1
09/29/2025 3:19 AM
LEAK TEST 0.20 GPH
SLOPE 0.05 GPH

09/05/2025 1:52 AM
LEAK TEST 0.20 GPH
SLOPE -0.02 GPH

08/06/2025 3:54 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH

07/08/2025 9:58 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH

06/08/2025 7:19 AM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH

05/09/2025 5:02 AM
LEAK TEST 0.20 GPH
SLOPE -0.03 GPH

04/10/2025 12:47 AM
LEAK TEST 0.20 GPH
SLOPE -0.09 GPH

03/11/2025 11:59 AM
LEAK TEST 0.20 GPH
SLOPE -0.08 GPH

02/09/2025 12:44 AM
LEAK TEST 0.20 GPH
SLOPE -0.10 GPH

01/12/2025 7:47 AM
LEAK TEST 0.20 GPH
SLOPE -0.10 GPH

12/15/2024 1:47 AM
LEAK TEST 0.20 GPH
SLOPE -0.10 GPH

11/15/2024 3:03 AM
LEAK TEST 0.20 GPH
SLOPE -0.03 GPH

10/16/2024 3:05 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

09/17/2024 6:02 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

TANK 2
09/29/2025 4:34 PM
LEAK TEST 0.20 GPH
SLOPE -0.06 GPH

09/02/2025 9:54 PM
LEAK TEST 0.20 GPH
SLOPE 0.04 GPH

08/03/2025 11:38 PM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH

07/04/2025 11:39 PM
LEAK TEST 0.20 GPH
SLOPE -0.05 GPH

06/04/2025 11:28 PM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

05/05/2025 10:23 PM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH

04/05/2025 10:31 PM
LEAK TEST 0.20 GPH
SLOPE -0.03 GPH

03/06/2025 11:29 PM
LEAK TEST 0.20 GPH
SLOPE -0.00 GPH

02/04/2025 11:44 PM
LEAK TEST 0.20 GPH
SLOPE -0.02 GPH

01/05/2025 11:42 PM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

12/06/2024 7:35 PM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

11/06/2024 10:14 PM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH

10/07/2024 10:23 PM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

09/07/2024 10:33 PM
LEAK TEST 0.20 GPH
SLOPE 0.03 GPH

TANK 3

09/29/2025 4:46 PM
LEAK TEST 0.20 GPH
SLOPE -0.10 GPH

09/01/2025 7:41 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

08/02/2025 9:56 AM
LEAK TEST 0.20 GPH
SLOPE -0.03 GPH

07/03/2025 11:23 PM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH

06/03/2025 2:56 PM
LEAK TEST 0.20 GPH
SLOPE -0.07 GPH

05/04/2025 6:49 AM
LEAK TEST 0.20 GPH
SLOPE -0.03 GPH

04/04/2025 8:26 AM
LEAK TEST 0.20 GPH
SLOPE -0.02 GPH

03/05/2025 10:10 PM
LEAK TEST 0.20 GPH
SLOPE -0.03 GPH

02/03/2025 8:16 AM
LEAK TEST 0.20 GPH
SLOPE 0.07 GPH

01/04/2025 11:00 PM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH

12/05/2024 9:31 PM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

11/05/2024 11:02 PM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH

10/06/2024 11:29 PM
LEAK TEST 0.20 GPH