

PHILLIPS 66
720 S VANBUREN
SH. FISHMANA IN

05-15-23 12:25 PM

CSLI TEST RESULTS

05-15-23 12:25 PM

T 1:UNLEADED
PROVEE SERIAL NUM 831856
T 2:UNLEADED
PROVEE SERIAL NUM 831854

0.2 GAL/HR TEST
PER: 05-15-23 PASS

T 3:PREMIUM
PROVEE SERIAL NUM 831852

0.2 GAL/HR TEST
PER: 05-15-23 PASS

T 4:KEROSENE
PROVEE SERIAL NUM 831853

0.2 GAL/HR TEST
PER: 05-15-23 PASS

T 5:DIESEL
PROVEE SERIAL NUM 831855

0.2 GAL/HR TEST
PER: 05-15-23 PASS

T 6:RAVE GAS
PROVEE SERIAL NUM 830337

0.2 GAL/HR TEST
PER: 05-15-23 PASS

***** END *****

PHILLIPS 66
720 S VANBUREN
SH. FISHMANA IN

05-15-23 12:25 PM

LIQUID STATUS

05-15-23 12:25 PM

L 1:NL-1
SENEOR NORMAL

L 2:NL-2
SENEOR NORMAL

L 3:PREMIUM
SENEOR NORMAL

L 4:K-1
SENEOR NORMAL

L 5:DIESEL
SENEOR NORMAL

L 6:E-35
SENEOR NORMAL

***** END *****

PHILLIPS 66
720 S VANBUREN
SH. FISHMANA IN

05-15-23 12:26 PM

LEAK TEST REPORT

T 1:UNLEADED
PROVEE SERIAL NUM 831856

NO TEST DATA AVAILABLE

***** END *****

PHILLIPS 66
720 S VANBUREN
SH. FISHMANA IN

05-15-23 12:26 PM

LEAK TEST REPORT

T 2:UNLEADED