

PHILLIPS 66
720 S VANDUREN
SH.FSHAWANA IN

02-06-23 12:48 PM

CSLE TEST RESULTS

02-06-23 12:48 PM

T 1:UNLEADED
PROEE SERIAL NUM 831856
T 2:UNLEADED
PROEE SERIAL NUM 831854

0.2 GAL/HR TEST
PER: 02-08-23 PASS

T 3:PREMIUM
PROEE SERIAL NUM 831852

0.2 GAL/HR TEST
PER: 02-08-23 PASS

T 4:KEROSENE
PROEE SERIAL NUM 831853

0.2 GAL/HR TEST
PER: 02-08-23 PASS

T 5:DIESEL
PROEE SERIAL NUM 831855

0.2 GAL/HR TEST
PER: 02-08-23 PASS

T 6:RACE GAS
PROEE SERIAL NUM 830337

0.2 GAL/HR TEST
PER: 02-08-23 PASS

* * * * * END * * * * *

PHILLIPS 66
720 S VANDUREN
SH.FSHAWANA IN

02-06-23 12:48 PM

LIQUID STATUS

02-06-23 12:48 PM

L 1:NL-1
SENEOR NORMAL

L 2:NL-2
SENEOR NORMAL

L 3:PREMIUM
SENEOR NORMAL

L 4:K-1
SENEOR NORMAL

L 5:DIESEL
SENEOR NORMAL

L 6:E-35
SENEOR NORMAL

* * * * * END * * * * *

PHILLIPS 66
720 S VANDUREN
SH.FSHAWANA IN

02-06-23 12:48 PM

LEAK TEST REPORT

T 1:UNLEADED
PROEE SERIAL NUM 831856

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PHILLIPS 66
720 S VANDUREN
SH.FSHAWANA IN

02-06-23 12:48 PM

LEAK TEST REPORT