

Tanks Data		30 DAYS WALK THROUGH INSPECTION	
UST Facility I.D. (FID) # 24944	Contact Number		
Facility Name Phillips 66	Contact email		
Address 720 S. Van Buren St. Shipshewana 46605	Date of Inspection 7/12/22		
Operator on Duty Name	Name of the Person Conducting Inspection Josh Rider		
Operator Training			
Operator Training current	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Registration/Notification Form			
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Release Detection			
Release Detection Method	☒ ATG ☐ DIM	☐ SIR ☐ IC ☐ Other	
Make and Model	VR TLS-350		
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Fill Ports			
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Piping/STP Sumps			
Are Sumps Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
Under Dispenser Containments (UDC)			
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			
Operator on Duty Name	Signature	Date 7/12/22	
317-645-0215		www.tanksdata.com	

20220516

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

07-12-22 6:31 PM

CSLD TEST RESULTS

07-12-22 6:31 PM

T 1: UNLEADED
PROEE SERIAL NUM 831856
T 2: UNLEADED
PROEE SERIAL NUM 831854

0.2 GAL/HR TEST
PER: 07-12-22 PASS

T 3: PREMIUM
PROEE SERIAL NUM 831852

0.2 GAL/HR TEST
PER: 07-12-22 PASS

T 4: KEROSENE
PROEE SERIAL NUM 831853

0.2 GAL/HR TEST
PER: 07-12-22 PASS

T 5: DIESEL
PROEE SERIAL NUM 831855

0.2 GAL/HR TEST
PER: 07-12-22 PASS

T 6: RACE GAS
PROEE SERIAL NUM 830337

0.2 GAL/HR TEST
PER: 07-12-22 PASS

* * * * * END * * * * *