

PHILLIPS 66
720 S VANBUREN
SH. FSHEMANA IN

03-23-24 1:55 PM

SYSTEM STATUS REPORT

Q 2:LN EQUIP FAULT ALM

PHILLIPS 66
720 S VANBUREN
SH. FSHEMANA IN

03-23-24 1:55 PM

CSLD TEST RESULTS

03-23-24 1:55 PM

T 1:UNLEADED
PROEE SERIAL NUM 831856
T 2:UNLEADED
PROEE SERIAL NUM 831854

0.2 GAL/HR TEST
PER: 03-23-24 PASS

T 3:PREMIUM
PROEE SERIAL NUM 831852

0.2 GAL/HR TEST
PER: 03-23-24 PASS

T 4:KEROSENE
PROEE SERIAL NUM 831853

0.2 GAL/HR TEST
PER: 03-23-24 PASS

T 5:DIESEL
PROEE SERIAL NUM 831855

0.2 GAL/HR TEST
PER: 03-23-24 PASS

T 6:FACE GAS
PROEE SERIAL NUM 830337

0.2 GAL/HR TEST
PER: 03-23-24 PASS

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SH. FSHEMANA IN

03-23-24 1:55 PM

PRESSURE LINE LEAK
TEST RESULTS

Q 1:NL-1

3.0 GAL/HR RESULTS:

LAST TEST:
03-23-24 1:44 PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 80
SINCE MIDNIGHT : 36

0.20 GAL/HR RESULTS:

03-21-24 8:24 PM PASS