

PHILLIPS 66
720 S VANBUREN
SHEPSHEWANA IN

04-29-25 5:14 PM

LEAK TEST REPORT

T 1:UNLEADED
PROEE SERIAL NUM 831856

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SHEPSHEWANA IN

04-29-25 5:14 PM

CSLD TEST RESULTS

04-29-25 5:14 PM

T 1:UNLEADED
PROEE SERIAL NUM 831856

T 2:UNLEADED
PROEE SERIAL NUM 831854

0.2 GAL/HR TEST
PER: 04-29-25 PASS

T 3:PREMIUM
PROEE SERIAL NUM 831852

0.2 GAL/HR TEST
PER: 04-29-25 PASS

T 4:KEROSENE
PROEE SERIAL NUM 831853

0.2 GAL/HR TEST
PER: 04-29-25 PASS

T 5:DIESEL
PROEE SERIAL NUM 831855

0.2 GAL/HR TEST
PER: 04-29-25 PASS

T 6:RADE GAS
PROEE SERIAL NUM 830337

0.2 GAL/HR TEST
PER: 04-29-25 PASS

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SHEPSHEWANA IN

04-29-25 5:14 PM

LEAK TEST REPORT

T 2:UNLEADED
PROEE SERIAL NUM 831854

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SHEPSHEWANA IN

04-29-25 5:14 PM

LIQUID STATUS

04-29-25 5:14 PM

L 1:NL-1
SENSOR NORMAL

L 2:NL-2
SENSOR NORMAL

L 3:PREMIUM
SENSOR NORMAL

L 4:K-1
SENSOR NORMAL

L 5:DIESEL
SENSOR NORMAL

L 6:E-35
SENSOR NORMAL

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

04-29-25 5:14 PM

PRESSURE LINE LEAK
TEST RESULTS

Q 1:NL-1

3.0 GAL/HR RESULTS:

LAST TEST:

04-29-25 5:04 PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 56

SINCE MIDNIGHT : 47

0.20 GAL/HR RESULTS:

04-27-25 1:47 AM PASS
04-21-25 7:28 PM PASS
04-17-25 6:33 PM PASS
04-13-25 2:25 PM PASS
04-09-25 7:58 PM PASS
04-05-25 10:17 PM PASS
03-30-25 10:00 AM PASS
03-26-25 2:06 AM PASS
03-20-25 8:47 PM PASS
03-14-25 8:51 PM PASS

0.10 GAL/HR RESULTS:

11-14-24 3:48 AM PASS
05-13-24 12:51 AM PASS
11-12-23 7:17 AM PASS
05-13-23 1:35 AM PASS
11-10-22 12:00 AM PASS
05-07-22 2:24 AM PASS
09-01-21 10:11 PM PASS
02-28-21 12:34 AM PASS
08-25-20 11:52 PM PASS
02-23-20 11:21 PM PASS

Q 2:NL-2

3.0 GAL/HR RESULTS:

LAST TEST:

04-29-25 4:41 PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 13

SINCE MIDNIGHT : 11

0.20 GAL/HR RESULTS:

04-29-25 8:07 AM PASS
04-25-25 10:56 PM PASS
04-21-25 2:14 PM PASS
04-17-25 2:13 PM PASS
04-13-25 12:40 PM PASS
04-09-25 6:11 PM PASS
04-05-25 9:59 PM PASS
04-01-25 6:22 AM PASS
03-26-25 12:16 PM PASS
03-22-25 6:16 PM PASS

0.10 GAL/HR RESULTS:

03-22-25 8:49 PM PASS
09-19-24 11:29 AM PASS
03-19-24 6:36 AM PASS
08-24-23 11:07 PM PASS
02-21-23 9:23 PM PASS
08-21-22 10:03 PM PASS
02-18-22 8:29 AM PASS
08-16-21 7:58 AM PASS
02-13-21 6:58 PM PASS
08-13-20 9:35 PM PASS

Q 3:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:

04-29-25 5:05 PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 74

SINCE MIDNIGHT : 63

0.20 GAL/HR RESULTS:

04-27-25 10:14 PM PASS
04-25-25 5:08 AM PASS
04-21-25 7:30 PM PASS
04-17-25 11:09 PM PASS
04-13-25 6:43 PM PASS
04-09-25 10:22 PM PASS
04-07-25 7:05 AM PASS
04-03-25 7:38 PM PASS
03-30-25 11:23 AM PASS
03-26-25 10:03 PM PASS

0.10 GAL/HR RESULTS:

02-28-25 1:01 AM PASS
08-24-24 4:42 AM PASS
02-19-24 12:30 AM PASS
08-20-23 2:13 AM PASS
02-15-23 7:25 AM PASS
08-13-22 11:54 PM PASS
02-08-22 10:03 PM PASS
08-08-21 8:21 AM PASS
02-05-21 7:46 PM PASS
08-05-20 9:00 PM PASS

Q 4:DIESEL

3.0 GAL/HR RESULTS:

LAST TEST:
04-29-25 4:53 PM PASS

NUMEER OF TESTS PASSED
PREV 24 HOURS : 18
SINCE MIDNIGHT : 17

0.20 GAL/HR RESULTS:

04-29-25 11:59 AM PASS
04-25-25 7:20 AM PASS
04-21-25 1:34 PM PASS
04-17-25 11:21 AM PASS
04-13-25 12:39 PM PASS
04-09-25 10:10 AM PASS
04-05-25 9:04 AM PASS
04-01-25 9:32 AM PASS
03-28-25 10:07 AM PASS
03-24-25 10:47 AM PASS

0.10 GAL/HR RESULTS:

02-24-25 7:53 AM PASS
08-24-24 4:32 PM PASS
02-22-24 4:18 PM PASS
08-22-23 8:47 AM PASS
02-19-23 2:54 PM PASS
08-19-22 9:12 AM PASS
02-14-22 9:09 PM PASS
08-12-21 11:04 PM PASS
02-09-21 8:02 PM PASS
08-09-20 2:33 PM PASS

Q 5:E-35

3.0 GAL/HR RESULTS:

LAST TEST:
04-29-25 4:56 PM PASS
NUMEER OF TESTS PASSED : 2
PREV 24 HOURS : 2
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

04-25-25 4:01 PM PASS
04-19-25 4:52 PM PASS
04-07-25 3:19 PM PASS
03-26-25 7:26 PM PASS
03-20-25 2:31 PM PASS
03-12-25 2:38 PM PASS
03-08-25 4:27 PM PASS
02-20-25 5:51 PM PASS
02-08-25 3:43 PM PASS
01-27-25 3:38 PM PASS

0.10 GAL/HR RESULTS:

11-06-24 3:06 PM PASS
04-20-24 11:53 AM PASS
10-23-23 3:38 PM PASS
04-22-23 6:37 PM PASS
10-14-23 2:51 PM PASS
04-09-22 12:52 PM PASS
10-05-22 11:34 PM PASS
09-02-21 6:42 PM PASS
03-26-20 5:36 PM PASS
03-26-20 5:08 PM PASS

Q 6:K-1

3.0 GAL/HR RESULTS:

LAST TEST:
04-10-25 2:51 PM PASS
NUMEER OF TESTS PASSED : 0
PREV 24 HOURS : 0
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

03-28-25 6:16 PM PASS
02-06-25 10:46 AM PASS
02-18-25 11:01 AM PASS
02-12-25 12:42 PM PASS
01-06-25 12:37 PM PASS
01-18-25 6:45 PM PASS
01-19-25 10:00 PM PASS
01-09-25 11:00 AM PASS
12-14-24 11:00 AM PASS

0.10 GAL/HR RESULTS:

11-06-24 3:06 PM PASS
04-20-24 11:53 AM PASS
10-23-23 3:38 PM PASS
04-22-23 6:37 PM PASS
10-14-23 2:51 PM PASS
04-09-22 12:52 PM PASS
10-05-22 11:34 PM PASS
09-02-21 6:42 PM PASS
03-26-20 5:36 PM PASS
03-26-20 5:08 PM PASS

END

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

04-29-25 5:15 PM

LEAK TEST REPORT

T 3:PREMIUM
PROEE SERIAL NUM 831852

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

04-29-25 5:15 PM

LEAK TEST REPORT

T 4:KEROSENE
PROEE SERIAL NUM 831853

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

04-29-25 5:15 PM

LEAK TEST REPORT

T 5:DIESEL
PROEE SERIAL NUM 831855

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

04-29-25 5:15 PM

LEAK TEST REPORT

T 6:RACE GAS
PROEE SERIAL NUM 830337

NO TEST DATA AVAILABLE

* * * * * END * * * * *