

T 4:KEROSENE
PROEE SERIAL NUM 831853
0.2 GAL/HR TEST PASS
PER: 07-19-25

T 5:DIESEL
PROEE SERIAL NUM 831855
0.2 GAL/HR TEST PASS
PER: 07-19-25

T 6:ACE GAS
PROEE SERIAL NUM 830337
0.2 GAL/HR TEST PASS
PER: 07-19-25

***** END *****

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

07-19-25 6:16 PM

LIQUID STATUS
- - - - -
07-19-25 6:16 PM

L 1:NL-1
SENSOR NORMAL

L 2:NL-2
SENSOR NORMAL

L 3:PREMIUM
SENSOR NORMAL

L 4:K-1
SENSOR NORMAL

L 5:DIESEL
SENSOR NORMAL

L 6:E-35
FUEL ALARM

***** END *****

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

07-19-25 6:16 PM

PRESSURE LINE LEAK
TEST RESULTS

Q 1:NL-1

3.0 GAL/HR RESULTS:
LAST TEST:
07-19-25 5:38 PM PASS
NUMBER OF TESTS PASSED
PREV 24 HOURS : 72
SINCE MIDNIGHT : 59

0.20 GAL/HR RESULTS:
07-16-25 9:47 PM PASS
07-10-25 11:33 PM PASS
07-06-25 11:58 PM PASS
07-03-25 12:05 AM PASS
06-30-25 1:48 AM PASS
06-24-25 9:56 PM PASS
06-21-25 12:23 AM PASS
06-16-25 10:40 PM PASS
06-12-25 6:34 AM PASS
06-08-25 7:24 AM PASS

0.10 GAL/HR RESULTS:
05-17-25 10:56 PM PASS
11-14-24 3:48 AM PASS
05-13-24 12:51 AM PASS
11-12-23 7:17 AM PASS
05-13-23 1:35 AM PASS
11-10-22 12:00 AM PASS
05-07-22 2:24 AM PASS
09-01-21 10:11 PM PASS
02-28-21 12:34 AM PASS
08-25-20 11:52 PM PASS

Q 2:NL-2

3.0 GAL/HR RESULTS:
LAST TEST:
07-19-25 5:23 PM PASS
NUMBER OF TESTS PASSED
PREV 24 HOURS : 12
SINCE MIDNIGHT : 9

0.20 GAL/HR RESULTS:
07-16-25 11:35 AM PASS
07-10-25 8:36 AM PASS
07-06-25 10:30 AM PASS
07-02-25 10:13 PM PASS
06-28-25 5:51 PM PASS
06-24-25 2:38 PM PASS
06-20-25 9:04 PM PASS
06-14-25 3:29 PM PASS
06-10-25 7:19 PM PASS
06-06-25 6:33 PM PASS

0.10 GAL/HR RESULTS:
03-22-25 8:49 PM PASS
09-19-24 11:29 AM PASS
03-19-24 6:36 AM PASS
08-24-23 11:07 PM PASS
02-21-23 9:23 PM PASS
08-21-22 10:03 PM PASS
02-18-22 8:29 AM PASS
08-16-21 7:58 AM PASS
02-13-21 6:58 PM PASS
08-13-20 9:35 PM PASS

Q 2: FUEL-2
 3.0 GAL/HR RESULTS:
 LAST TEST:
 07-19-25 5:23 PM PASS
 NUMBER OF TESTS PASSED
 PREV 24 HOURS :
 SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:
 07-16-25 11:35 AM PASS
 07-10-25 8:36 AM PASS
 07-05-25 10:30 AM PASS
 06-28-25 10:13 PM PASS
 06-24-25 5:51 PM PASS
 06-10-25 2:38 PM PASS
 06-10-25 9:04 PM PASS
 06-05-25 3:29 PM PASS
 06-05-25 7:19 PM PASS
 06-05-25 6:33 PM PASS

0.10 GAL/HR RESULTS:
 03-22-25 8:49 PM PASS
 09-19-25 11:29 AM PASS
 03-19-24 6:29 AM PASS
 08-24-24 11:36 AM PASS
 02-21-23 9:07 PM PASS
 08-21-23 10:23 PM PASS
 02-18-22 8:03 PM PASS
 08-16-21 7:29 AM PASS
 02-13-21 8:58 AM PASS
 08-13-20 9:35 PM PASS

Q 3: PREMIUM
 3.0 GAL/HR RESULTS:
 LAST TEST:
 07-19-25 5:35 PM PASS
 NUMBER OF TESTS PASSED
 PREV 24 HOURS : 100
 SINCE MIDNIGHT : 85

0.20 GAL/HR RESULTS:
 07-06-25 11:37 PM PASS
 06-30-25 10:43 PM PASS
 06-26-25 1:34 AM PASS
 06-20-25 11:34 PM PASS
 06-14-25 1:38 AM PASS
 06-08-25 10:24 PM PASS
 06-06-25 6:19 AM PASS
 06-02-25 7:12 AM PASS
 05-29-25 5:05 AM PASS
 05-25-25 8:06 PM PASS

0.10 GAL/HR RESULTS:
 02-25-25 1:01 AM PASS
 08-24-24 4:42 AM PASS
 02-19-24 12:30 AM PASS
 08-20-23 2:13 AM PASS
 02-15-23 7:25 AM PASS
 08-13-22 11:54 PM PASS
 02-08-22 10:03 PM PASS
 08-08-21 8:21 AM PASS
 02-05-21 7:46 PM PASS
 08-05-20 9:00 PM PASS

Q 4: DIESEL
 3.0 GAL/HR RESULTS:
 LAST TEST:
 07-19-25 6:15 PM PASS
 NUMBER OF TESTS PASSED
 PREV 24 HOURS : 25
 SINCE MIDNIGHT : 21

0.20 GAL/HR RESULTS:
 07-16-25 8:13 PM PASS
 07-12-25 6:57 PM PASS
 07-08-25 1:26 PM PASS
 07-04-25 8:33 PM PASS
 06-30-25 9:53 PM PASS
 06-26-25 8:38 PM PASS
 06-24-25 5:43 AM PASS
 06-20-25 7:31 PM PASS
 06-16-25 10:54 AM PASS
 06-12-25 4:37 AM PASS

0.10 GAL/HR RESULTS:
 02-24-25 7:53 AM PASS
 08-24-24 4:32 PM PASS
 02-22-24 4:18 PM PASS
 08-22-23 8:47 AM PASS
 02-19-23 2:54 PM PASS
 08-19-22 9:12 AM PASS
 02-14-22 9:09 PM PASS
 08-12-21 11:04 PM PASS
 02-09-21 8:02 PM PASS
 08-09-20 2:33 PM PASS

Q 5: E-35
 3.0 GAL/HR RESULTS:
 LAST TEST:
 07-19-25 10:53 AM PASS
 NUMBER OF TESTS PASSED
 PREV 24 HOURS : 4
 SINCE MIDNIGHT : 4

REV OF TESTS PASSED 25
 24 HOURS : 21
 SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

07-16-25	8:13 PM	PASS
07-12-25	6:57 PM	PASS
07-08-25	1:26 PM	PASS
06-30-25	8:33 PM	PASS
06-26-25	9:53 PM	PASS
06-24-25	8:38 PM	PASS
06-20-25	5:43 AM	PASS
06-16-25	7:31 PM	PASS
06-12-25	10:54 AM	PASS
	4:37 AM	PASS

0.10 GAL/HR RESULTS:

02-24-25	7:53 AM	PASS
08-24-24	4:32 PM	PASS
08-22-24	4:18 PM	PASS
02-19-23	8:47 AM	PASS
08-19-23	2:54 PM	PASS
02-14-22	9:12 AM	PASS
08-12-22	9:09 PM	PASS
02-09-21	11:04 PM	PASS
08-09-21	8:02 PM	PASS
08-09-20	2:33 PM	PASS

Q 5:E-35

3.0 GAL/HR RESULTS:

LAST TEST:
 07-19-25 10:53 AM PASS

NUMEER OF TESTS PASSED 4
 PREV 24 HOURS : 4
 SINCE MIDNIGHT : 4

0.20 GAL/HR RESULTS:

07-14-25	11:06 PM	PASS
07-10-25	9:46 AM	PASS
06-30-25	7:02 PM	PASS
06-26-25	6:58 PM	PASS
06-22-25	10:58 AM	PASS
06-14-25	9:56 AM	PASS
06-08-25	1:50 PM	PASS
05-31-25	9:21 AM	PASS
05-27-25	11:55 AM	PASS
05-23-25	4:48 PM	PASS

0.10 GAL/HR RESULTS:

05-09-25	6:13 PM	PASS
11-06-24	3:06 PM	PASS
04-30-24	11:53 AM	PASS
10-23-23	3:38 PM	PASS
04-22-23	6:37 PM	PASS
10-14-22	2:51 PM	PASS
04-09-22	5:52 PM	PASS
10-05-21	12:34 PM	PASS
04-02-21	11:42 PM	PASS
09-26-20	6:36 PM	PASS

Q 6:K-1

3.0 GAL/HR RESULTS:

LAST TEST:
 07-09-25 9:43 AM FAIL

NUMEER OF TESTS PASSED 0
 PREV 24 HOURS : 0
 SINCE MIDNIGHT : 0

0.20 GAL/HR RESULTS:

05-21-25	11:44 AM	FAIL
04-30-25	9:33 AM	PASS
03-28-25	6:16 PM	PASS
03-06-25	4:46 PM	PASS
02-18-25	10:01 AM	PASS
02-12-25	11:42 AM	PASS
02-06-25	6:37 PM	PASS
01-25-25	12:45 PM	PASS
01-19-25	6:27 PM	PASS
01-09-25	4:03 PM	PASS

0.10 GAL/HR RESULTS:

11-12-24	11:10 AM	PASS
04-26-24	3:04 PM	PASS
10-19-23	2:37 PM	PASS
04-08-23	5:27 PM	PASS
09-30-22	12:20 PM	PASS
02-12-22	12:59 PM	PASS
08-06-21	5:33 AM	PASS
10-24-20	6:15 PM	PASS
04-13-20	4:55 PM	PASS
10-10-19	3:47 PM	PASS

* * * * * END * * * * *