

PHILLIPS 66
720 S VANBUREN
SHEPHEWANA IN

05-26-25 4:37 PM

LEAK TEST REPORT

T 1:UNLEADED
PROEE SERIAL NUM 831856

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SHEPHEWANA IN

05-26-25 4:37 PM

CSLD TEST RESULTS

05-26-25 4:37 PM

T 1:UNLEADED
PROEE SERIAL NUM 831856

T 2:UNLEADED
PROEE SERIAL NUM 831854

0.2 GAL/HR TEST
PER: 05-26-25 PASS

T 3:PREMIUM
PROEE SERIAL NUM 831852

0.2 GAL/HR TEST
PER: 05-26-25 PASS

T 4:KEROSENE
PROEE SERIAL NUM 831853

0.2 GAL/HR TEST
PER: 05-26-25 PASS

T 5:DIESEL
PROEE SERIAL NUM 831855

0.2 GAL/HR TEST
PER: 05-26-25 PASS

T 6:RADE GAS
PROEE SERIAL NUM 830337

0.2 GAL/HR TEST
PER: 05-26-25 PASS

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SHEPHEWANA IN

05-26-25 4:37 PM

LEAK TEST REPORT

T 2:UNLEADED
PROEE SERIAL NUM 831854

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PHILLIPS 66
720 S VANBUREN
SHEPHEWANA IN

05-26-25 4:37 PM

LIQUID STATUS

05-26-25 4:37 PM

L 1:NL-1
SENSOR NORMAL

L 2:NL-2
SENSOR NORMAL

L 3:PREMIUM
SENSOR NORMAL

L 4:K-1
SENSOR NORMAL

L 5:DIESEL
SENSOR NORMAL

L 6:E-35
SENSOR NORMAL

* * * * * END * * * * *

720 S HARBOR
FORDIANA IN

05-26-25 4:37 PM

PRESSURE LINE LEAK
TEST RESULTS

G 1:NL-1

3.0 GAL/HR RESULTS:

LAST TEST:
05-26-25 4:32 PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 68
SINCE MIDNIGHT : 55

0.20 GAL/HR RESULTS:

05-25-25 10:54 AM PASS
05-21-25 9:00 PM PASS
05-17-25 10:13 PM PASS
05-15-25 11:20 PM PASS
05-10-25 12:05 AM PASS
05-07-25 6:09 AM PASS
05-03-25 4:31 AM PASS
04-29-25 10:43 PM PASS
04-27-25 1:47 AM PASS
04-21-25 7:28 PM PASS

0.10 GAL/HR RESULTS:

05-17-25 10:56 PM PASS
11-14-24 3:48 AM PASS
05-13-24 12:51 AM PASS
11-12-23 7:17 AM PASS
05-10-23 1:35 AM PASS
11-10-22 12:00 AM PASS
05-07-22 2:24 AM PASS
09-01-21 10:11 PM PASS
02-26-21 12:34 AM PASS
08-25-20 11:52 PM PASS

G 2:NL-2

3.0 GAL/HR RESULTS:

LAST TEST:
05-26-25 3:58 PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 16
SINCE MIDNIGHT : 15

0.20 GAL/HR RESULTS:

05-25-25 11:13 AM PASS
05-21-25 9:09 AM PASS
05-17-25 9:31 AM PASS
05-11-25 2:29 PM PASS
05-07-25 8:51 PM PASS
05-03-25 7:24 AM PASS
04-29-25 8:07 AM PASS
04-25-25 10:56 PM PASS
04-21-25 2:14 PM PASS
04-17-25 2:13 PM PASS

0.10 GAL/HR RESULTS:

03-22-25 8:49 PM PASS
09-19-24 11:29 AM PASS
03-19-24 6:36 AM PASS
08-24-23 11:07 PM PASS
02-21-23 9:23 PM PASS
08-21-22 10:03 PM PASS
02-18-22 8:29 AM PASS
08-16-21 7:58 AM PASS
02-13-21 6:58 PM PASS
08-13-20 9:35 PM PASS

G 3:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
05-26-25 4:31 PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 95
SINCE MIDNIGHT : 80

0.20 GAL/HR RESULTS:

05-25-25 8:06 PM PASS
05-19-25 10:22 PM PASS
05-13-25 9:36 PM PASS
05-10-25 1:24 AM PASS
05-07-25 6:08 AM PASS
05-01-25 11:28 PM PASS
04-27-25 10:14 PM PASS
04-25-25 5:08 AM PASS
04-21-25 7:30 PM PASS
04-17-25 11:09 PM PASS

0.10 GAL/HR RESULTS:

02-25-25 1:01 AM PASS
08-24-24 4:42 AM PASS
02-19-24 12:30 AM PASS
08-20-23 2:13 AM PASS
02-15-23 7:25 AM PASS
08-13-22 11:54 PM PASS
02-08-22 10:03 PM PASS
08-08-21 8:21 AM PASS
02-05-21 7:46 PM PASS
08-05-20 9:00 PM PASS

G 4:DIESEL

3.0 GAL/HR RESULTS:

LAST TEST:
05-26-25 4:32 PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 29
SINCE MIDNIGHT : 20

0.20 GAL/HR RESULTS:

05-25-25 7:28 PM PASS
05-21-25 10:44 PM PASS
05-17-25 6:19 PM PASS
05-13-25 10:00 PM PASS
05-09-25 11:53 AM PASS
05-07-25 2:26 AM PASS
05-03-25 8:44 AM PASS
04-29-25 11:59 AM PASS
04-25-25 7:20 AM PASS
04-21-25 1:34 PM PASS

0.10 GAL/HR RESULTS:

02-24-25 7:53 AM PASS
08-24-24 4:32 PM PASS
02-22-24 4:18 AM PASS
02-22-23 8:47 AM PASS
08-22-23 2:54 PM PASS
02-19-23 9:12 AM PASS
08-19-22 9:09 PM PASS
02-14-22 11:04 PM PASS
08-12-21 8:02 PM PASS
02-09-21 2:33 PM PASS

Q 5:E-35

3.0 GAL/HR RESULTS:

LAST TEST:
05-26-25 4:18 PM PASS
NUMBER OF TESTS PASSED 2
PREV 24 HOURS : 2
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

05-23-25	4:48 PM	PASS
05-19-25	10:40 PM	PASS
05-15-25	1:12 PM	PASS
05-09-25	5:01 PM	PASS
05-07-25	4:18 PM	PASS
05-01-25	10:20 AM	PASS
04-25-25	4:01 PM	PASS
04-19-25	4:52 PM	PASS
04-07-25	3:19 PM	PASS
03-26-25	7:26 PM	PASS

0.10 GAL/HR RESULTS:

05-09-25	6:10 PM	PASS
11-06-24	3:06 PM	PASS
04-30-24	11:53 AM	PASS
10-23-23	3:38 PM	PASS
04-22-23	6:37 PM	PASS
10-14-22	2:51 PM	PASS
04-09-22	5:52 PM	PASS
10-05-21	12:34 PM	PASS
04-02-21	11:42 PM	PASS
09-26-20	6:36 PM	PASS

Q 6:K-1

3.0 GAL/HR RESULTS:

LAST TEST:
05-22-25 10:26 AM PASS
NUMBER OF TESTS PASSED 0
PREV 24 HOURS : 0
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

05-21-25	11:44 AM	FAIL
04-30-25	9:33 AM	PASS
03-28-25	6:16 PM	PASS
03-06-25	4:46 PM	PASS
02-18-25	10:01 AM	PASS
02-12-25	11:42 AM	PASS
02-06-25	6:37 PM	PASS
01-25-25	12:45 PM	PASS
01-19-25	6:27 PM	PASS
01-09-25	4:03 PM	PASS

0.10 GAL/HR RESULTS:

11-12-24	11:10 AM	PASS
04-26-24	3:04 PM	PASS
10-19-23	2:37 PM	PASS
04-08-23	5:27 PM	PASS
09-30-22	12:20 PM	PASS
02-12-22	12:59 PM	PASS
08-06-21	5:33 AM	PASS
10-24-20	6:15 PM	PASS
04-13-20	4:55 PM	PASS
10-10-19	3:47 PM	PASS

***** END *****

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

05-26-25 4:37 PM

LEAK TEST REPORT

T 3:PREMIUM
PROEE SERIAL NUM 831852

NO TEST DATA AVAILABLE

***** END *****

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

05-26-25 4:37 PM

LEAK TEST REPORT

T 4:KEROSENE
PROEE SERIAL NUM 831853

NO TEST DATA AVAILABLE

***** END *****

PHILLIPS 66
720 S VANBUREN
SHIPSHEWANA IN

05-26-25 4:38 PM

LEAK TEST REPORT

T 6:RACE GAS
PROEE SERIAL NUM 830337

NO TEST DATA AVAILABLE

***** END *****