

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE: SIMONTON LAKE MARATHON
ADDRESS: 51451 SR 19 N
CITY,ST,ZIP: ELKHART, IN 46514

DATE: 12/29/2022

ATG FUNCTIONALITY

ATG MAKE AND MODEL

TANK NUMBER

PRODUCT

TANK VOLUME

TANK DIAMETER

TANK PROBE HAS NO DAMAGED PARTS?

DAMAGED OR MISSING PARTS REPLACED?

FLOATS MOVE FREELY ON STEM?

FUEL FLOAT AGREES W/ CONSOLE?

INCH LEVEL WATER FLOAT ACTIVATES ALARM?

WATER FLOAT AGREES W/ CONSOLE?

INCH LEVEL OVERFILL ACTIVATES ALARM?

OVERFILL ALARM AGREES W/ CONSOLE?

AUDIBLE SOUNDS ALARM?

ALL SENSORS LABELED CORRECTLY?

STP/UDC SENSORS ACTIVATE ALARM?

INTERSTITIAL TANK SENSORS ACTIVATE ALARM?

.2 MONTHLY MONITORING ACTIVE?

BATTERY BACKUP IS FUNCTIONAL?

RESULT

COMMENTS:

VR 350

1	2	3	4	5
UNL	UNL	PREM		
8022	4018	4018		
96	72	72		
N	N	N		
NA	NA	NA		
Y	Y	Y		
Y	Y	Y		
2	2	2		
Y	Y	Y		
83	62	62		
Y	Y	Y		
Y	Y	Y		
NA	NA	NA		
Y	Y	NA		
NA	NA	NA		
Y	Y	Y		
YES				
PASS	PASS	PASS		

TECHNICIAN: JOHN LANNOM

CERTIFICATION:

UC20129333