



THE OSCAR W. LARSON COMPANY

CORPORATE OFFICE: 10100 DIXIE HIGHWAY, CLARKSTON, MI 48348

PH: (248) 620-0070 · FAX: (248) 620-0072



Call Number: 220502-0337

APPENDIX C-3

SPILL BUCKET INTEGRITY TESTING HYDROSTATIC TEST METHOD SINGLE AND DOUBLE-WALLED VACUUM TEST METHOD

#5
(9063)

Facility Name: SIMONTON LAKE MARATHON 202481		Owner:				
Address: 51451 State Route 19		Address:				
City, State, Zip Code: Elkhart, IN, 46514		City, State, Zip Code:				
Facility I.D. #:		Phone #:				
Testing Company: Oscar W. Larson		Phone #:			Date: 12/19/2022	
This procedure is to test the leak integrity of single- and double-walled spill buckets. See PEI/RP1200, Section 6.2 for hydrostatic test method, Section 6.3 for single-walled vacuum test method and Section 6.4 for double-walled vacuum test method.						
Tank Number	2					
Product Stored	Regular Unlead					
Spill Bucket Capacity	5 gal.					
Manufacturer	OPW					
Construction	☒ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled
Test Type	☒ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled
Spill Bucket Type	☒ Product ☐ Vapor	☐ Product ☐ Vapor	☐ Product ☐ Vapor	☐ Product ☐ Vapor	☐ Product ☐ Vapor	☐ Product ☐ Vapor
Liquid and debris removed from spill bucket?*	☒ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Visual Inspection (No cracks, loose parts or separation of the bucket from the fill pipe.)	☒ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail
Tank riser cap included in test?	☒ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA
Is drain valve included in test?	☐ Yes ☐ No ☒ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA
Starting Level	12 3/4"					
Test Start Time	1:20 PM					
Ending Level	12 3/4"					
Test End Time	2:20 PM					
Test Period	1 hour					
Level Change	0"					
Pass/fail criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8 inch; Vacuum single-walled only: Maintain at least 26 inches water column; Vacuum double-walled: maintain at least 12 inches water column.						
Test Results	☒ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail
Comments: Passed						

*All liquids and debris must be disposed of properly.

Tester's Name Joshua Wetli Tester's Signature