

oil
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 9063

Facility Name MARATHON

Address 5151 State Road 19, Elkhardt

Operator on Duty Name L. V. 46517

Contact Number

Contact email

Date of Inspection 09/15/24

Name of the Person Conducting Inspection AKS 417

Operator Training

Operator Training
☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Release Detection Method

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Release Detection

Release Detection
ATG ☒ VR TL550 ☐ CIM

Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Spill Buckets

Spill Buckets
☐ Yes ☒ No

Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?
Are the Spill Bucket in good condition and free of damage/cracks

Fill Ports
☐ Yes ☒ No

Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Pipeline/STP Sumps
☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

Under Dispenser Containments (UDC)
☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

317-645-0215

tanksdata@gmail.com

Date

www.tanksdata.com