



# CATHODIC PROTECTION

TEST DATE: 8/29/2023  
 LOCATION NAME: Red D Mart  
 LOCATION ADDRESS: 51451 State Road 19 North  
 LOCATION CITY/STATE: Elkhart, IN 46514  
 LOCATION PHONE: 0  
 LOCATION CONTACT: Virendar Kumar

OWNER NAME: Tanks Data  
 OWNER ADDRESS: 51451 State Road 19 North  
 OWNER CITY/STATE/ZIP: Elkhart, IN 46514  
 LOCATION FID#: 09063  
 WORK ORDER NO: NE-0555

SYSTEM TYPE:  
 TEMPERATURE:  
 CONDITIONS:  
 TIME:

| TANK NO                 | 1     | 2     | 3 | 4 | 5 | 6 |
|-------------------------|-------|-------|---|---|---|---|
| PRODUCT STORED          | RUL   |       |   |   |   |   |
| TANK CAPACITY           | 8000  |       |   |   |   |   |
| TANK SIZE               |       |       |   |   |   |   |
| TANK CONTACT            | LINE  |       |   |   |   |   |
| REFERENCE CELL LOCATION | LOCAL | STP   |   |   |   |   |
| VOLTAGE READING         |       | -1133 |   |   |   |   |
| REFERENCE CELL LOCATION | LOCAL | TM    |   |   |   |   |
| VOLTAGE READING         |       | -1112 |   |   |   |   |
| REMOTE VOLTAGE          |       | -1001 |   |   |   |   |
| RESULT                  | PASS  |       |   |   |   |   |

JOHN LANNOM  
 CERTIFIED TECHNICIAN NAME (printed)

*[Signature]*  
 CERTIFIED TECHNICIAN SIGNATURE

CERT NO: UC20129333  
 EXPIRATION DATE: 8/17/2024

| LEGEND |                               |
|--------|-------------------------------|
| TW     | TEST WIRE                     |
| TB     | TANK BOTTOM                   |
| TM     | TANK MONITORING PROBE OPENING |
| INT    | INTERSTITIAL OPENING          |

## SITE DIAGRAM

