



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # <u>9663</u>	Contact Number
Facility Name <u>Marathon</u>	Contact email
Address <u>5145 State Road 1946319</u>	Date of Inspection <u>07-23-2025</u>
Operator on Duty Name	Name of the Person Conducting Inspection <u>Curtis</u>

Operator Training current	Operator Training		Operator Notified	
	☐ Yes ☐ No		☐ Yes ☐ No	
Is Registration current with correct owner, operator etc.	Registration/Notification Form		Operator Notified	
	☐ Yes ☐ No		☐ Yes ☐ No	
Release Detection Method	Release Detection		☐ SIR	☐ IC
Make and Model <u>VRTLS-350</u>	☒ ATG ☒ CIM		☐ Other	
Does it have paper?	☒ Yes ☐ No		Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No		Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No		Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No		Operator Notified	☐ Yes ☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	Spill Buckets		Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No		Operator Notified	☒ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	Fill Ports		Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☐ Yes ☒ No		Operator Notified	☒ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	Piping/STP Sumps		Operator Notified	☒ Yes ☐ No
	☐ Yes ☒ No			
	Under Dispenser Containments (UDC)			
	☐ Yes ☒ No			

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

tanksdata@gmail.com

Date 07-23-2025
www.tanksdata.com