

SIMONTON LAKE
MARTHON
51415 ST RT 19
ELKHART IN

SEP 29, 2025 3:48 PM

CSLD TEST RESULTS

SEP 29, 2025 3:48 PM

T 1:UNLEADED
PROBE SERIAL NUM 572331

0.2 GAL/HR TEST
PER: SEP 29, 2025 INCR

T 2:UNLEADED
PROBE SERIAL NUM 674923

0.2 GAL/HR TEST
PER: SEP 29, 2025 FAIL

T 3:PREM
PROBE SERIAL NUM 596778

0.2 GAL/HR TEST
PER: SEP 29, 2025 PASS

* * * * * END * * * * *

SIMONTON LAKE
MARTHON
51415 ST RT 19
ELKHART IN

SEP 29, 2025 3:48 PM

LIQUID STATUS

SEP 29, 2025 3:48 PM

NONE

* * * * * END * * * * *