

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) #	9063	Contact Number	
Facility Name	MAKATHON	Contact email	
Address	51451 State Road 19, Sikeston	Date of Inspection	02/27/25
Operator on Duty Name	N 46514	Name of the Person Conducting Inspection	AKSMIT

Operator Training current

Operator Training

Operator Notified

Yes

No

Is Registration current with correct owner, operator etc.

Registration/Notification Form

Operator Notified

Yes

No

Release Detection Method

Release Detection

Operator Notified

Yes

No

Make and Model

Release Detection

Operator Notified

Yes

No

Does it have paper?

Release Detection

Operator Notified

Yes

No

Is it in Alarm mode?

Release Detection

Operator Notified

Yes

No

Interstitial Monitoring Sensor Status Normal

Release Detection

Operator Notified

Yes

No

Necessary Monthly Printout Taken

Release Detection

Operator Notified

Yes

No

Spill Buckets

Release Detection

Operator Notified

Yes

No

Are Spill Buckets Clean and free from water, debris, product etc?

Release Detection

Operator Notified

Yes

No

Are the Spill Bucket in good condition and free of damage/cracks

Release Detection

Operator Notified

Yes

No

Fill Ports

Release Detection

Operator Notified

Yes

No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Release Detection

Operator Notified

Yes

No

Piping/STP Sumps

Release Detection

Operator Notified

Yes

No

Are Sumps Clean and free from water, debris, product etc?

Release Detection

Operator Notified

Yes

No

Under Dispenser Containments (UDC)

Release Detection

Operator Notified

Yes

No

Are UDCs clean and free from water, debris, product etc?

Release Detection

Operator Notified

Yes

No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com

20220516