

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) # 9063
 Facility Name Marathon
 Address 51451 State Road 19, Ellijah
 Operator on Duty Name 317-46514

Contact Number
 Contact email
 Date of Inspection 09-27-25
 Name of the Person Conducting Inspection Nelson Singh

Operator Training current

Operator Training
☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection
☒ ATG ☐ CIM

☐ SIR

☐ IC

☐ Other

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal
 Necessary Monthly Printout Taken

Spill Buckets

☒ Yes ☐ No

Operator Notified ☒ Yes ☐ No

☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?
 Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

Operator Notified ☒ Yes ☐ No

☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS
 FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com