

SIMONTON LAKE
MARTHON
51415 ST RT 19
ELKHART IN

JUL 23, 2025 6:29 PM

CSLD TEST RESULTS

- - - - -
JUL 23, 2025 6:29 PM

T 1:UNLEADED
PROBE SERIAL NUM 572331

0.2 GAL/HR TEST
PER: JUL 23, 2025 INCR

T 2:UNLEADED
PROBE SERIAL NUM 674923

0.2 GAL/HR TEST
PER: JUL 23, 2025 FAIL

T 3:PREM
PROBE SERIAL NUM 596778

0.2 GAL/HR TEST
PER: JUL 23, 2025 PASS

* * * * * END * * * * *

SIMONTON LAKE
MARTHON
51415 ST RT 19
ELKHART IN

JUL 23, 2025 6:29 PM

LIQUID STATUS

- - - - -
JUL 23, 2025 6:29 PM

NONE

* * * * * END * * * * *