

JACOBS

Professional Services, LLC

Petroleum Construction and Environmental Services Specialists						
Liquid Sensor Functionality Test						
Facility Information:			Owner Information:			
University Marathon			Good Oil Company			
111 E. Ireland Road			1201 N. US Hwy 35			
South Bend, Indiana 46614			Winamac, Indiana 46996			
Enter Facility I.D. #			574-532-7858			
Jacobs Professional Services, LLC			Dean Good/ Paul Singh		8/28/2023	
This data sheet is used to determine whether liquid sensors located in the interstitial space of UST systems can detect presence of water or fuel.						
See PEI/RP1200, Section 8.3 for the inspection procedure.						
Sensor Location	STP	STP	STP	INTERSTITIAL	INTERSTITIAL	
Product Stored	RUL	PUL	DSL	RUL	PUL-DSL	
Sensor Brand & Model	Veeder-Root 208	Veeder-Root 208	Veeder-Root 208	Veeder-Root 208	Veeder-Root 208	
Type of Sensor, Discriminating or Non-Discriminating(Standard)	☐ Discriminating ☒ Standard	☐ Discriminating ☒ Standard	☐ Discriminating ☒ Standard	☐ Discriminating ☒ Standard	☐ Discriminating ☒ Standard	☐ Discriminating ☐ Standard
Test Liquid	☒ Water ☐ Product	☒ Water ☐ Product	☒ Water ☐ Product	☒ Water ☐ Product	☒ Water ☐ Product	☐ Water ☐ Product
Is the ATG console clear of any active or recurring warnings or alarms regarding the leak sensor?	☒ Yes ☐ No In Alarm why	☒ Yes ☐ No In Alarm why	☒ Yes ☐ No In Alarm why	☒ Yes ☐ No In Alarm why	☒ Yes ☐ No In Alarm why	☐ Yes ☐ No In Alarm why
Is the sensor alarm circuit operational?	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☐ Yes ☐ No
Has sensor been inspected and in good operating condition	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☐ Yes ☐ No
When placed in the test liquid, does the sensor trigger an alarm?	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☐ Yes ☐ No
When an alarm is triggered, is the sensor properly identified on the ATG Console?	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☒ Yes ☐ No	☐ Yes ☐ No
A "No" to any Question indicates a test failure.						
Test Results	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☐ Pass ☐ Fail
Comments:						
Edward Jacobs			Edward Jacobs UC2000663334			