

JACOBS

Professional Services, LLC

Petroleum Construction and Environmental Services Specialists						
Piping Secondary Containment Integrity Testing						
Facility Information:			Owner Information:			
University Marathon			Good Oil Company			
111 E. Ireland Road			1201 N. US Hwy 35			
South Bend, Indiana 46614			Winamac, Indiana 46996			
Enter Facility I.D. #			574-532-7858			
Jacobs Professional Services, LLC			Dean Good/ Paul Singh		8/28/2023	
This data sheet is to test the integrity of the interstitial space of double-wall piping. See PEI/RP1200, Section 5 for the inspection procedure.						
Tank Number	1	2	3	1	2	
Product Stored	RUL	PUL	DSL	RUL	PUL	
Piping Material	OPW	OPW	OPW	OPW	OPW	
Piping Run	117'	112'	46'	66'	62'	
Test Start Time	4:30:00 PM	4:30:00 PM	4:30:00 PM	4:30:00 PM	4:30:00 PM	
Initial Test Pressure, psig	4.5	3.5	5	3	4	
Test End Time	5:30:00 PM	5:30:00 PM	5:30:00 PM	5:30:00 PM	5:30:00 PM	
Final Test Pressure, psig	4.5	3.5	5	3	4	
Pressure Change, (No reduction in psig for Pass)	0	0	0	0	0	
Pass/Fail Criteria: Must not have reduction in pressure for pass.						
Test Results	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☐ Pass ☐ Fail
Comments:						
Edward Jacobs			Edward Jacobs UC2000663334			