

UNIVERSITY MARATHON
111 IRELAND RD
SOUTH BEND IN
574-291-3283

MAY 30, 2025 7:12 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 850746

TEST STARTING TIME:
MAY 30, 2025 1:00 AM

HEIGHT = 87.9 INCHES
WATER = 0.0 INCHES
TEMP = 40.8 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 5601.4 GAL
PERCENT VOLUME = 27.2

LEAK TEST RESULTS
RATE = -12.59 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

UNIVERSITY MARATHON
111 IRELAND RD
SOUTH BEND IN
574-291-3283

MAY 30, 2025 7:12 PM

LIQUID STATUS

MAY 30, 2025 7:12 PM

L 1:UNLEADED STP BUMP
SENSOR NORMAL

L 2:PREMIUM STP BUMP
SENSOR NORMAL

L 3:DIESEL STP BUMP
SENSOR NORMAL

L 4:UNLEADED INTERSTICE
SENSOR NORMAL

L 5:PREM-DBL INTERSTICE
SENSOR NORMAL

***** END *****

UNIVERSITY MARATHON
111 IRELAND RD
SOUTH BEND IN
574-291-3283

MAY 30, 2025 7:12 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 850747

TEST STARTING TIME:
MAY 30, 2025 1:00 AM

HEIGHT = 45.3 INCHES
WATER = 0.0 INCHES
TEMP = 59.1 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1877.8 GAL
PERCENT VOLUME = 46.5

LEAK TEST RESULTS
RATE = -6.34 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

UNIVERSITY MARATHON
111 IRELAND RD
SOUTH BEND IN
574-291-3283

MAY 30, 2025 7:12 PM

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 850745

TEST STARTING TIME:
JAN 14, 2022 1:00 AM

HEIGHT = 33.2 INCHES
WATER = 0.0 INCHES
TEMP = 43.7 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2402.0 GAL
PERCENT VOLUME = 35.8

LEAK TEST RESULTS
RATE = -0.86 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****