

Oil
Tank Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	16564	Contact Number	
Facility Name	MARATHON	Contact email	
Address	111 E Ireland, South Bend,	Date of Inspection	02/23/25
Operator on Duty Name	CV 46612	Name of the Person Conducting Inspection	AKSM17

Operator Training current	☐ Yes ☐ No	Operator Training	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Registration/Notification Form	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Release Detection Method	☒ ATG ☐ DIM	Release Detection	☒ ATG ☐ DIM	Operator Notified	☐ Yes ☐ No
Make and Model	CR 725-352		☐ SIR	Operator Notified	☐ Yes ☐ No
Does it have paper?	☒ Yes ☐ No			Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☐ Yes ☒ No			Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No			Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☐ Yes ☐ No			Operator Notified	☐ Yes ☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Spill Buckets	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Fill Ports	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Pipeline/STP Sumps	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Under Dispenser Containments (UDC)	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No			Operator Notified	☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com