

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	16564	Contact Number	
Facility Name	MARATHON	Contact email	
Address	111 E. Island, South Bend, IN 46614	Date of Inspection	01/27/25
Operator on Duty Name		Name of the Person Conducting Inspection	AKM17

Operator Training current	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Release Detection Method	☒ ATG	☐ TIM	Operator Notified	☐ Yes	☐ No
Make and Model	VR TUS 350				
Does it have paper?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No

Operator on Duty Name: _____ Signature: _____ Date: _____