

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

MAY 12, 2023 1:31 PM

CSLD TEST RESULTS

MAY 12, 2023 1:31 PM

T 1:KERO
PROBE SERIAL NUM 106024

0.2 GAL/HR TEST
PER: MAY 12, 2023 PASS

T 2:DIESEL
PROBE SERIAL NUM 105974

0.2 GAL/HR TEST
PER: MAY 12, 2023 PASS

T 3:RNL
PROBE SERIAL NUM 106026

0.2 GAL/HR TEST
PER: MAY 12, 2023 PASS

T 4:FREM
PROBE SERIAL NUM 167606

0.2 GAL/HR TEST
PER: MAY 12, 2023 PASS

*****END*****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

MAY 12, 2023 1:31 PM

LIGUID STATUS

MAY 12, 2023 1:31 PM

L 3:SUMP
SENSOR NORMAL

L 4:SUMP
SENSOR NORMAL

*****END*****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

MAY 12, 2023 1:31 PM

LEAK TEST REPORT

T 1:KERO
PROBE SERIAL NUM 106024

NO TEST DATA AVAILABLE

*****END*****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

MAY 12, 2023 1:32 PM

LEAK TEST REPORT

T 2:DIESEL
PROBE SERIAL NUM 105974

NO TEST DATA AVAILABLE

*****END*****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

MAY 12, 2023 1:32 PM

LEAK TEST REPORT

T 3:RNL
PROBE SERIAL NUM 106026

NO TEST DATA AVAILABLE

*****END*****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

MAY 12, 2023 1:32 PM

LEAK TEST REPORT

T 4:FREM
PROBE SERIAL NUM 167606

NO TEST DATA AVAILABLE

*****END*****