

Tanks Data		30 DAYS WALK THROUGH INSPECTION	
UST Facility I.D. (FID) # 19871	Contact Number		
Facility Name BP Snappy	Contact email		
Address 53031 SR 13 Middlebury 46540	Date of Inspection 7/12/22		
Operator on Duty Name	Name of the Person Conducting Inspection Josh Rider		
Operator Training			
Operator Training current	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Registration/Notification Form			
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Release Detection			
Release Detection Method	☒ ATG ☐ CIM	☐ SIR	☐ IC ☐ Other
Make and Model	VR TLS-350		
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☐ Yes ☒ No	Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Fill Ports			
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Piping/STP Sumps			
Are Sumps Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
Under Dispenser Containments (UDC)			
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			
Operator on Duty Name	Signature	Date 7/12/22	
317-645-0215		www.tanksdata.com	

20220516

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JUL 12, 2022 4:54 PM

CSLD TEST RESULTS

JUL 12, 2022 4:54 PM

T 1: KERO
PROBE SERIAL NUM 106024

0.2 GAL/HR TEST
PER: JUL 12, 2022 PASS

T 2: DIESEL
PROBE SERIAL NUM 105974

0.2 GAL/HR TEST
PER: JUL 12, 2022 PASS

T 3: RNL
PROBE SERIAL NUM 106026

0.2 GAL/HR TEST
PER: JUL 12, 2022 PASS

T 4: PREM
PROBE SERIAL NUM 167606

0.2 GAL/HR TEST
PER: JUL 12, 2022 PASS

***** END *****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JUL 12, 2022 4:54 PM

LIQUID STATUS

JUL 12, 2022 4:54 PM

L 3: SUMP
SENSOR NORMAL

L 4: SUMP
SENSOR NORMAL

***** END *****