

L 3:FUEL ALARM  
L 4:FUEL ALARM

BP SNAPPY  
53031 SR 13  
MIDDLEBURY IN  
574-825-7627

MAR 11, 2024 11:58 AM

CSLD TEST RESULTS

MAR 11, 2024 11:58 AM

T 1:KERO  
PROBE SERIAL NUM 106024

0.2 GAL/HR TEST  
PER: MAR 11, 2024 PASS

T 2:DIESEL  
PROBE SERIAL NUM 105974

0.2 GAL/HR TEST  
PER: MAR 11, 2024 PASS

T 3:RNL  
PROBE SERIAL NUM 106026

0.2 GAL/HR TEST  
PER: MAR 11, 2024 PASS

T 4:PREM  
PROBE SERIAL NUM 167606

0.2 GAL/HR TEST  
PER: MAR 11, 2024 PASS

\*\*\*\*\* END \*\*\*\*\*

BP SNAPPY  
53031 SR 13  
MIDDLEBURY IN  
574-825-7627

MAR 11, 2024 11:58 AM

LIQUID STATUS

MAR 11, 2024 11:58 AM

L 3:SUMP  
FUEL ALARM

L 4:SUMP  
FUEL ALARM

\*\*\*\*\* END \*\*\*\*\*

BP SNAPPY  
53031 SR 13  
MIDDLEBURY IN  
574-825-7627

MAR 11, 2024 11:58 AM

LEAK TEST REPORT

T 1:KERO  
PROBE SERIAL NUM 106024

NO TEST DATA AVAILABLE

\*\*\*\*\* END \*\*\*\*\*