

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

FEB 26, 2024 11:43 AM

SYSTEM STATUS REPORT

L 3:FUEL ALARM

L 4:FUEL ALARM

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

FEB 26, 2024 11:43 AM

CSLD TEST RESULTS

FEB 26, 2024 11:43 AM

T 1:KERO
PROBE SERIAL NUM 106024

0.2 GAL/HR TEST
PER: FEB 26, 2024 PASS

T 2:DIESEL
PROBE SERIAL NUM 105974

0.2 GAL/HR TEST
PER: FEB 26, 2024 PASS

T 3:RNL
PROBE SERIAL NUM 106026

0.2 GAL/HR TEST
PER: FEB 26, 2024 PASS

T 4:PREM
PROBE SERIAL NUM 167606

0.2 GAL/HR TEST
PER: FEB 26, 2024 PASS

***** END *****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

FEB 26, 2024 11:43 AM

LIQUID STATUS

FEB 26, 2024 11:43 AM

L 3:SUMP
FUEL ALARM

L 4:SUMP