

APPENDIX C-5 UT OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE

TEST DATE: 8/29/2023

LOCATION NAME: Snappy Food Mart

LOCATION ADDRESS: 53031 State Road 13

LOCATION CITY/STATE: Middlebury, IN 46540

LOCATION PHONE: 0

LOCATION CONTACT: Virender Kumar

OWNER NAME: Tanks Data

OWNER ADDRESS: 53031 State Road 13

OWNER CITY/STATE/ZIP: Middlebury, IN 46540

LOCATION FID#: 19871

WORK ORDER NO: NE-0553

This data sheet is for inspection automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.

Product Grade	KER	DSL	RUL	PUL		
Tank Number	1	2	3	4		
Tank Volume, gallons	2649	11627	12077	8078		
Tank Diameter, inches	71.25	92	120	120		
Overfill Prevention Device Brand	STRAIGHT	STRAIGHT	STRAIGHT	STRAIGHT		
Type	Ball Float Valve	Ball Float Valve	Ball Float Valve	Ball Float Valve	-	-

AUTOMATIC SHUTOFF DEVICE INSPECTION

1. Drop tube removed from tank?						
2. Drop tube and float mechanisms free of debris?						
3. Float moves freely without binding and poppet moves into flow path?						
4. Bypass valve in the drop tube open and fress of blockage (if present)?						
5. Flapper adjusted to shut off flow at 95% capacity?*						

BALL FLOAT VALVE INSPECTION **

1. Tank Top fitting vapor-tight and leak-free?	YES	YES	YES	YES		
2. Ball float cage free of debris?						
3. Ball free of holes an dcarcks and moves freely in cage?						
4. Vent hole in pipe open and near top of tank?						
5. Ball float pipe proper length to restrict flow at 90% capacity?***						

A "No" to any item in Lines 1-5 indicates a test failure.

AUTO SHUT OFF DEVICE TEST RESULTS						
BALL FLOAT VALVE INSPECTION RESULTS	UNTESTABLE	UNTESTABLE	UNTESTABLE	UNTESTABLE		

COMMENTS:

BALL FLOAT ARE UNTESTABLE,TRIED TO REMOVE ALL FOUR VAPOR ADAPTORS WITH NO SUCCESS,ADAPTOR WILL HAVE TOO BE CUT OFF AND REPLACED

* Use manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity.

** If a ball float is found to fail in inspection, another method of overfill must be used.

*** Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.

0

SERVICE TECHNICIAN NAME (printed)
CHRIS HOWARD

CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE
Chris Howard

CERTIFIED TECHNICIAN SIGNATURE

CERT NO: U3-UC111000, U1-UC111458
EXPIRATION DATE: 8/18/2024, 10/06/24