

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 19871

Facility Name B3P

Address 53031 SR 13, Middlebury, VT 05756

Operator on Duty Name IN 46540

Name of the Person Conducting Inspection AKSHIT SAHARAN

Operator Training current

Operator Training ☒ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form ☐ Yes ☒ No

Release Detection Method

Release Detection ☒ ATG ☐ DIM ☐ SIR ☐ IC ☐ Other

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Spill Buckets

Spill Buckets ☒ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

Are the Spill Bucket in good condition and free of damage/cracks

Fill Ports ☒ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Piping/STP Sumps ☒ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?

Operator Notified ☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com