

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JUL 26, 2024 3:29 PM

CSLD TEST RESULTS

JUL 26, 2024 3:29 PM

T 1:KERO
PROBE SERIAL NUM 106024

0.2 GAL/HR TEST
PER: JUL 26, 2024 PASS

T 2:DIESEL
PROBE SERIAL NUM 105974

0.2 GAL/HR TEST
PER: JUL 26, 2024 PASS

T 3:RNL
PROBE SERIAL NUM 167606

0.2 GAL/HR TEST
PER: JUL 26, 2024 PASS

T 4:PREM
PROBE SERIAL NUM 687569

0.2 GAL/HR TEST
PER: JUL 26, 2024 PASS

* * * * * END * * * * *

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JUL 26, 2024 3:29 PM

LIQUID STATUS

JUL 26, 2024 3:29 PM

L 3:SUMP
SENSOR NORMAL

L 4:SUMP
SENSOR NORMAL

* * * * * END * * * * *

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JUL 26, 2024 3:29 PM

LEAK TEST REPORT

T 1:KERO
PROBE SERIAL NUM 106024

NO TEST DATA AVAILABLE

***** END *****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JUL 26, 2024 3:29 PM

LEAK TEST REPORT

T 2:DIESEL
PROBE SERIAL NUM 105974

NO TEST DATA AVAILABLE

***** END *****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JUL 26, 2024 3:29 PM

LEAK TEST REPORT

T 3:RNL
PROBE SERIAL NUM 167606

NO TEST DATA AVAILABLE

***** END *****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JUL 26, 2024 3:29 PM

LEAK TEST REPORT

T 4:PREM
PROBE SERIAL NUM 687569

NO TEST DATA AVAILABLE

***** END *****