



APPENDIX C-3

SPILL BUCKET INTEGRITY TESTING HYDROSTATIC TEST METHOD SINGLE- AND DOUBLE-WALLED VACUUM TEST METHOD

TEST DATE:	8/29/2023	OWNER NAME:	Tanks Data
LOCATION NAME:	Snappy Food Mart	OWNER ADDRESS:	53031 State Road 13
LOCATION ADDRESS:	53031 State Road 13	OWNER CITY/STATE/ZIP:	Middlebury, IN 46540
LOCATION CITY/STATE:	Middlebury, IN 46540		
LOCATION PHONE:	0	LOCATION FID#:	19871
LOCATION CONTACT:	Virender Kumar	WORK ORDER NO:	NE-0553

This procedure is to test the leak integrity of single- and double-walled spill buckets. See PEI/RP1200 Section 6.2 for hydrostatic test method. Section 6.3 for single-walled vacuum test method and Section 6.4 for double-walled vacuum test method.

Tank Number	1	2	3	4		
Product Stored	RUL	PUL	DSL	KER		
Spill Bucket Capacity	5 GALLON	5 GALLON	5 GALLON	5 GALLON		
Manufacturer	EBW	EBW	EBW	EBW		
Construction	Single-Walled	Single-Walled	Single-Walled	Single-Walled	-	-
Test Type	Hydrostatic	Hydrostatic	Hydrostatic	Hydrostatic	-	-
Spill Bucket Type	Product	Product	Product	Product	-	-
Liquid & Debris Removed From Spill Bucket?*	YES	YES	YES	YES	-	-
Visual Inspection (No cracks, loose parts, or separation of the bucket from the fill pipe)	PASS	PASS	PASS	PASS	-	-
Tank riser cap included in test?	YES	YES	YES	YES	-	-
Drain valve included in test?	YES	YES	YES	YES		
Starting Level	11.5	14.5	11	11.75		
Test Start Time	8:20	8:20	8:20	8:20		
Ending Level	11.5	14.5	11	9		
Test End Time	9:20	9:20	9:20	9:20		
Test Period	1HR	1HR	1HR	1HR		
Level Change	0	0	0	-2.75		

Pass/Fail criteria: Must pass vision inspection. Hydrostatic: Water level drop of less than 1/8 inch; Vacuum single-walled only: Maintain at least 26 inches water column; Vacuum double-walled maintain at least 12 inches water column.

TEST RESULTS	PASS	PASS	PASS	FAIL	-	-
--------------	------	------	------	------	---	---

COMMENTS:

* All liquids and debris must be disposed of properly

0

SERVICE TECHNICIAN NAME (printed)

CHRIS HOWARD

CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE

Chris Howard

CERTIFIED TECHNICIAN SIGNATURE

CERT NO: 10, U1-UC111458

EXPIRATION DATE: 8/18/2024, 10/06