



APPENDIX C-7
AUTOMATIC TANK GAUGE
OPERATION INSPECTION

TEST DATE: 8/30/2023
LOCATION NAME: Snappy Food Mart
LOCATION ADDRESS: 53031 State Road 13
LOCATION CITY/STATE: Middlebury, IN 46540
LOCATION PHONE: 0
LOCATION CONTACT: Virendar Kumar
OWNER NAME: Tanks Data
OWNER ADDRESS: 53031 State Road 13
OWNER CITY/STATE/ZIP: Middlebury, IN 46540
LOCATION FID#: 19871
WORK ORDER NO: NE-0551

This procedure is to determine whether the automatic tank gauge (ATG) is operating properly. See PEI/RP1200 Section 8.2 for the inspection procedure. The procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.

Tank Number	1	2	3	4		
Product Stored	KER	DSL	RUL	PUL		
ATG Brand and Model	VEEDER-ROOT TLS350	VEEDER-ROOT TLS350	VEEDER-ROOT TLS350	VEEDER-ROOT TLS350		
1. Tank Volume, gallons	2649	11627	12077	8078		
2. Tank Diameter, inches	72"	92"	120"	120"		
3. After removing the ATG from the tank, it has been inspected and any damaged or missing parts replaced?	YES	YES	YES	YES		
4. Float moves freely on the stem without binding?	YES	YES	YES	YES		
5. Fuel float level agrees with the value programmed into the console?	YES	YES	YES	YES		
6. Water float level agrees with the value programmed into the console?	YES	YES	YES	YES		
7. Inch level from bottom of stem when 90% alarm is triggered.	64.8"	82.8"	108"	108"		
8. Inch level at which the overfill alarm activates corresponds with the valve programmed in the gauge?	YES	YES	YES	YES		
9. Inch level from bottom when the water float first triggers an alarm.	2"	2"	2"	2"		
10. Inch level at which the water float alarm activates corresponds with the valve programmed in the gauge?	YES	YES	YES	YES		

If any answers in Lines 3, 4, 5, or 6 are "No", the system has failed the test.

TEST RESULTS	PASS	PASS	PASS	PASS		
--------------	------	------	------	------	--	--

COMMENTS:

* All liquids must be disposed of properly.

0
SERVICE TECHNICIAN NAME (printed)

ADAM WILDER
CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE

CERTIFIED TECHNICIAN SIGNATURE

CERT NO: UC112310
EXPIRATION DATE: 1/23/2025