



EZY CHECK SYSTEMS PRODUCT LINE TESTER DATA SHEET

TEST DATE: 8/30/2023
LOCATION NAME: Snappy Food Mart
LOCATION ADDRESS: 53031 State Road 13
LOCATION CITY/STATE: Middlebury, IN 46540
LOCATION PHONE: 0
LOCATION CONTACT: Virendar Kumar

WORK ORDER NO: NE-0551
LOCATION FID#: 19871

APPLIED PRESSURE: 50PSI

#1	PRODUCT TYPE:		RUL		
TIME	DATA	-/+	GPL	RES	GPH
11:20	23	0	0.0037	0.0000	0.0000
11:35	22	1	0.0037	0.0037	0.0148
11:50	22	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
FINAL RESULT		PASS		0.0148	

#2	PRODUCT TYPE:			PUL		
TIME	DATA	-/+	GPL	RES	GPH	
11:20	78	0	0.0037	0.0000	0.0000	
11:35	75	3	0.0037	0.0111	0.0444	
11:50	73	2	0.0037	0.0074	0.0296	
			0.0037			
			0.0037			
			0.0037			
FINAL RESULT		PASS		0.0444		

#3	PRODUCT TYPE:			DSL		
TIME	DATA	-/+	GPL	RES	GPH	
11:55	70	0	0.0037	0.0000	0.0000	
12:10	70	0	0.0037	0	0	
12:25	70	0	0.0037	0	0	
			0.0037			
			0.0037			
			0.0037			
FINAL RESULT		PASS		0		

#4	PRODUCT TYPE:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
FINAL RESULT		-			

#5	PRODUCT TYPE:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
FINAL RESULT		-			

#6	PRODUCT TYPE:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
FINAL RESULT			-		

0

SERVICE TECHNICIAN NAME (printed)

ADAM WILDER

CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE

CERTIFIED TECHNICIAN SIGNATURE

CERT NO: UC112310

EXPIRATION DATE: 1/23/2025