

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JAN 2, 2024 2:33 PM

CSLD TEST RESULTS

JAN 2, 2024 2:33 PM

T 1:KERO
PROBE SERIAL NUM 106024

0.2 GAL/HR TEST
PER: JAN 2, 2024 PASS

T 2:DIESEL
PROBE SERIAL NUM 105974

0.2 GAL/HR TEST
PER: JAN 2, 2024 PASS

T 3:RNL
PROBE SERIAL NUM 106026

0.2 GAL/HR TEST
PER: JAN 2, 2024 PASS

T 4:FREM
PROBE SERIAL NUM 167606

0.2 GAL/HR TEST
PER: JAN 2, 2024 PASS

***** END *****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JAN 2, 2024 2:33 PM

LIQUID STATUS

JAN 2, 2024 2:33 PM

L 3:SUMP
SENSOR NORMAL

L 4:SUMP
SENSOR NORMAL

***** END *****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JAN 2, 2024 2:33 PM

LEAK TEST REPORT

T 1:KERO
PROBE SERIAL NUM 106024

NO TEST DATA AVAILABLE

***** END *****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JAN 2, 2024 2:33 PM

LEAK TEST REPORT

T 2:DIESEL
PROBE SERIAL NUM 105974

NO TEST DATA AVAILABLE

***** END *****

BP SNAPPY
53031 SR 13
MIDDLEBURY IN
574-825-7627

JAN 2, 2024 2:33 PM

LEAK TEST REPORT

T 3:RNL
PROBE SERIAL NUM 106026

NO TEST DATA AVAILABLE

***** END *****

BP SNAPPY
53031 SR 13