

LIQUID SENSOR FUNCTIONALITY TESTING

TEST DATE: 8/30/2023
 LOCATION NAME: Snappy Food Mart
 LOCATION ADDRESS: 53031 State Road 13
 LOCATION CITY/STATE: Middlebury, IN 46540
 LOCATION PHONE: 0
 LOCATION CONTACT: Virendar Kumar

OWNER NAME: Tanks Data
 OWNER ADDRESS: 53031 State Road 13
 OWNER CITY/STATE/ZIP: Middlebury, IN 46540
 LOCATION FID#: 19871
 WORK ORDER NO: NE-0551

This procedure is to determine whether liquid sensors located in the interstitial space of UST systems are able to detect the presence of water and fuel. See PEI/RP1200 Section 8.3 for the test procedure.

Sensor Location	STP SUMP	STP SUMP	STP SUMP	STP SUMP		
Product Stored	RUL	PUL	DSL	KER		
Type of Sensor	NON-DISCRIMINATING	NON-DISCRIMINATING	NON-DISCRIMINATING	NON-DISCRIMINATING		
Test Liquid	WATER	WATER	WATER	WATER		
Is the ATG console clear of any active or recurring warnings or alarms regarding the leak sensor? If the sensor is in alarm and functioning, indicate why.	YES	YES	YES	YES		
Is the sensor alarm circuit operational?	YES	YES	YES	YES		
Has sensor been inspected and in good operating condition?	YES	YES	YES	YES		
When placed in the test liquid, does the sensor trigger an alarm?	YES	YES	YES	YES		
When an alarm is triggered, is the sensor properly identified on the ATG console?	YES	YES	YES	YES		
Any "NO" answers indicates the sensor fails the test.						
TEST RESULTS	PASS	PASS	PASS	PASS		
COMMENTS:						

0

SERVICE TECHNICIAN NAME (printed)

ADAM WILDER

CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE

CERTIFIED TECHNICIAN SIGNATURE

CERT NO: UC112310

EXPIRATION DATE: 1/23/2025