

BP SNAPPY  
53031 SR 13  
MIDDLEBURY IN  
574-825-7627  
MAY 26, 2025 3:16 PM  
LEAK TEST REPORT  
T 1:KERO  
PROBE SERIAL NUM 106024  
NO TEST DATA AVAILABLE  
\*\*\*\*\* END \*\*\*\*\*

BP SNAPPY  
53031 SR 13  
MIDDLEBURY IN  
574-825-7627  
MAY 26, 2025 3:16 PM  
CSLD TEST RESULTS  
MAY 26, 2025 3:16 PM  
T 1:KERO  
PROBE SERIAL NUM 106024  
0.2 GAL/HR TEST  
PER: MAY 26, 2025 PASS  
T 2:DIESEL  
PROBE SERIAL NUM 105974  
0.2 GAL/HR TEST  
PER: MAY 26, 2025 PASS  
T 3:RNL  
PROBE SERIAL NUM 167606  
0.2 GAL/HR TEST  
PER: MAY 26, 2025 PASS  
\*\*\*\*\* END \*\*\*\*\*

BP SNAPPY  
53031 SR 13  
MIDDLEBURY IN  
574-825-7627  
MAY 26, 2025 3:16 PM  
LEAK TEST REPORT  
T 2:DIESEL  
PROBE SERIAL NUM 105974  
NO TEST DATA AVAILABLE  
\*\*\*\*\* END \*\*\*\*\*

BP SNAPPY  
53031 SR 13  
MIDDLEBURY IN  
574-825-7627  
MAY 26, 2025 3:16 PM  
LIQUID STATUS  
-----  
MAY 26, 2025 3:16 PM  
L 3:SUMP  
SENSOR NORMAL  
L 4:SUMP  
SENSOR NORMAL  
\*\*\*\*\* END \*\*\*\*\*

BP SNAPPY  
53031 SR 13  
MIDDLEBURY IN  
574-825-7627  
MAY 26, 2025 3:16 PM  
LEAK TEST REPORT  
T 3:RNL  
PROBE SERIAL NUM 167606  
NO TEST DATA AVAILABLE  
\*\*\*\*\* END \*\*\*\*\*

BP SNAPPY  
53031 SR 13  
MIDDLEBURY IN  
574-825-7627  
MAY 26, 2025 3:16 PM  
LEAK TEST REPORT  
T 4:PREM  
PROBE SERIAL NUM 245257  
NO TEST DATA AVAILABLE  
\*\*\*\*\* END \*\*\*\*\*