

Tanks Data		30 DAYS WALK THROUGH INSPECTION	
UST Facility I.D. (FID) # 1634	Contact Number		
Facility Name Citgo	Contact email		
Address 1356 Portage Ave South Bend 46616	Date of Inspection 8/18/22		
Operator on Duty Name	Name of the Person Conducting Inspection Josh Rider		
Operator Training Operator Training current ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Registration/Notification Form Is Registration current with correct owner, operator etc. ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Release Detection Release Detection Method ☐ ATG ☒ CIM ☐ SIR ☐ C ☐ Other Make and Model Franklin FS TS-550 evo Does it have paper? ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No Is it in Alarm mode? ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No Interstitial Monitoring Sensor Status Normal ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No Necessary Monthly Printout Taken ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Spill Buckets Are Spill Buckets Clean and free from water, debris, product etc? ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No Are the Spill Bucket in good condition and free of damage/cracks ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Fill Ports Is Fill pipe cap tight and fill pipe free from any obstruction? ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Piping/STP Sumps Are Sumps Clean and free from water, debris, product etc? ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Under Dispenser Containments (UDC) Are UDCs clean and free from water, debris, product etc? ☐ Yes ☒ No Operator Notified ☒ Yes ☐ No			
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			
Operator on Duty Name	Signature	Date	
317-645-0215		www.tanksdata.com	20220516

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
08/18/2022 16:29:31

SCALD REPORT
Last Available

units: gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 10,039.0

Begin End
08/18/2022 08/18/2022
06:45:54 13:10:25
Result Pass
Slope 0.08
Status 0
Volume Qualify(%) 14

Premium
Premium
Capacity: 10,039.0

Begin End
08/24/2022 08/24/2022
07:23:44 08:50:36
Result Pass
Slope 0.05
Status 0
Volume Qualify(%) 14

Diesel
Diesel
Capacity: 8,271.0

Begin End
08/18/2021 08/19/2021
16:25:49 07:03:01
Result Pass