

Tanks Data		30 DAYS WALK THROUGH INSPECTION	
UST Facility I.D. (FID) #	1634	Contact Number	
Facility Name	Citgo	Contact email	
Address	1356 Portage Ave South Bend	Date of Inspection	9/30/22
Operator on Duty Name	46628	Name of the Person Conducting Inspection	Josh Rider
Operator Training Operator Training current ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Registration/Notification Form Is Registration current with correct owner, operator etc. ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Release Detection Release Detection Method ☒ ATG ☐ CIM ☐ SIR ☐ C ☐ Other			
Make and Model ☒ Franklin FS TS-550 evo Operator Notified ☐ Yes ☐ No			
Does it have paper? ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Is it in Alarm mode? ☐ Yes ☒ No Operator Notified ☐ Yes ☐ No			
Interstitial Monitoring Sensor Status Normal ☐ Yes ☒ No Operator Notified ☐ Yes ☐ No			
Necessary Monthly Printout Taken ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Spill Buckets Are Spill Buckets Clean and free from water, debris, product etc? ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Are the Spill Bucket in good condition and free of damage/cracks ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Fill Ports Is Fill pipe cap tight and fill pipe free from any obstruction? ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Piping/STP Sumps Are Sumps Clean and free from water, debris, product etc? ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No			
Under Dispenser Containments (UDC) Are UDCs clean and free from water, debris, product etc? ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No			
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			
Operator on Duty Name		Signature	
317-645-0215		Date	
		www.tanksdata.com	

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
09/30/2022 13:50:30

SCALD REPORT
Last Available
units: gal, in, °F

TANKS

Unleaded
Unleaded Capacity: 10,039.0
Begin 09/29/2022 09/30/2022
05:43:36 02:30:09
Result Pass
Slope 0.09
Status 0
Volume Qualify(%) 14

Premium
Premium Capacity: 10,039.0
Begin 09/30/2022 09/30/2022
04:23:02 05:49:50
Result Pass
Slope 0.04
Status 0
Volume Qualify(%) 14

Diesel
Diesel Capacity: 8,271.0
Begin 09/30/2022 09/30/2022
12:03:24 13:29:10
Result Pass
Slope 0.01
Status 0
Volume Qualify(%) 14

HN Food Plus
1356 Portage Ave.