

Tanks Data		30 DAYS WALK THROUGH INSPECTION	
UST Facility I.D. (FID) # 1634	Contact Number		
Facility Name Citgo	Contact email		
Address 1356 Portage Ave South Bend 46628	Date of Inspection 11/14/22		
Operator on Duty Name	Name of the Person Conducting Inspection Josh Rider		
Operator Training			
Operator Training current	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Registration/Notification Form			
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Release Detection			
Release Detection Method	☒ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other		
Make and Model	Franklin FS TS-550 evo		
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☐ Yes ☒ No	Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Fill Ports			
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Piping/STP Sumps			
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Under Dispenser Containments (UDC)			
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			
Operator on Duty Name	Signature	Date	
317-645-0215	tanksdata@gmail.com	www.tanksdata.com	

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
11/14/2022 15:00:12

SCALD REPORT
Last Available

units: gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 10,039.0

Begin End
11/13/2022 11/13/2022
02:47:15 04:48:41
Result Pass
Slope 0.06
Status 0
Volume Qualify(%) 14

Premium
Premium
Capacity: 10,039.0

Begin End
10/19/2022 10/19/2022
06:00:35 08:07:08
Result Pass
Slope 0.07
Status 0
Volume Qualify(%) 14

Diesel
Diesel
Capacity: 8,271.0

Begin End
11/14/2022 11/14/2022
12:46:24 14:46:54
Result Pass
Slope 0.01
Status 0
Volume Qualify(%) 14

20220516